

Non Routine Water Quality Results for Source and Distribution Water 2024

Sampling Point Name	Date Sampled	TC MPN / 100 ml	E-coli MPN / 100 ml	Comments
Finlay Sampling Station (#1)	2-Feb-24	<1	<1	Below MAC
Finlay Sampling Station (#2)	7-Feb-24	<1	<1	Below MAC
Oxford Reservoir	21-Mar-24	<1	<1	Below MAC
Amount of Times 1.0 or Higher:		0	0	