

Metal Results - 2019

Sample Location	Date Sampled	Arsenic mg/L	Copper mg/L	Lead mg/L	Iron mg/L	Manganese mg/L
Monthly Arsenic - Well 6	30-Jan-19	0.0088				
Monthly Arsenic - Well 7	30-Jan-19	0.0083				
Customer Concern - 1	13-Feb-19	0.0055	0.0091	0.00005	0.006	0.072
Monthly Arsenic - Well 6	27-Feb-19	0.0087				
Monthly Arsenic - Well 7	27-Feb-19	0.0083				
Customer Concern - 2	19-Mar-19	0.0058	0.0113	0.00016	0.007	0.076
Customer Concern - 3	20-Mar-19	0.0056	0.0074	0.00006	<0.004	0.052
Customer Concern - 4	26-Mar-19	0.0051	0.0181	0.00002	<0.004	0.077
Monthly Arsenic - Well 6	26-Mar-19	0.0079				
Monthly Arsenic - Well 7	28-Mar-19	0.0083				
Customer Concern - 5	2-Apr-19	0.0056	0.0042	0.00008	<0.004	0.097
Customer Concern - 6	25-Apr-19	<0.0001	0.0060	0.00004	<0.004	0.002
Customer Concern - 7	25-Apr-19	0.0001	0.0078	0.00005	<0.004	0.002
Customer Concern - 8	25-Apr-19	<0.0001	0.0025	0.00005	<0.004	0.002
Customer Concern - 9	26-Apr-19	0.0002	0.0054	0.00040	<0.004	0.008
Customer Concern - 10	26-Apr-19	0.0001	0.0034	0.00007	0.005	0.006
Customer Concern - 11	7-May-19	0.0003	0.0140	0.00154	<0.004	0.003
Customer Concern - 12	7-May-19	0.0002	0.0071	0.00090	<0.004	0.003
Customer Concern - 13	9-May-19	0.0002	0.0061	0.00009	<0.004	0.002
Customer Concern - 14	10-May-19	0.0002	0.0157	0.00028	<0.004	0.002
Customer Concern - 15	10-May-19	0.0001	0.0125	0.00007	<0.004	0.001
Customer Concern - 16	10-May-19	0.0003	0.0077	0.00024	<0.004	0.010
Customer Concern - 17	15-May-19	0.0004	0.0062	0.00028	<0.004	0.005
Customer Concern - 18	15-May-19	0.0005	0.0058	0.00042	0.004	0.009
Customer Concern - 19	15-May-19	0.0006	0.0053	0.00040	0.005	0.010
Customer Concern - 20	15-May-19	0.0006	0.0105	0.00045	<0.004	0.005
Customer Concern - 21	16-May-19	0.0006	0.0165	0.00117	<0.004	0.005
Customer Concern - 22 *Pre	6-Jun-19	0.0014	0.0200	0.00106	<0.004	0.004
Customer Concern - 22 *Post	6-Jun-19	<0.0001	<0.0005	<0.00001	<0.004	<0.001
Customer Concern - 23	4-Jul-19	0.0028	0.0061	0.00026	<0.004	0.005
Customer Concern - 24	4-Jul-19	0.0028	0.4708	0.02854	0.006	0.002
Customer Concern - 24 - Retest	11-Jul-19	0.0032	0.0039	<0.00001	<0.004	<0.001
Customer Concern - 25	11-Jul-19	0.0032	0.0169	0.00003	<0.004	<0.001
Customer Concern - 26	31-Jul-19	0.0035	0.0121	0.00018	<0.004	0.004
Customer Concern - 27	31-Jul-19	0.0033	0.0160	0.00001	<0.004	0.003
Customer Concern - 28	28-Aug-19	0.0037	0.0059	0.00040	0.008	0.007
Customer Concern - 29	28-Aug-19	0.0039	0.0078	0.00046	<0.004	<0.001
Customer Concern - 30	10-Sep-19	0.0039	0.0095	0.00016	<0.004	0.007
Customer Concern - 31	12-Sep-19	0.0040	0.0082	0.00022	<0.004	<0.001
Customer Concern - 32	19-Nov-19	0.0038	0.0022	0.00007	<0.004	<0.001
Customer Concern - 33	20-Dec-19	0.0033	0.0185	0.00020	<0.004	0.002
Nominal Detection Limit		0.0001	0.0005	0.00001	0.004	0.001
Guideline Limit		0.010	1.0	0.005	0.3	0.05

* Resident has a home filter system. Results are pre- and post-filter