

Bacterial Results - 2019

Microbiological Analysis MPN / 100mL	Date	Guideline Limit 0 per 100 ml	# of Samples	Pass	Fail	Guideline Comments
Total Coliforms	02-Jan-19	0 per 100 mL	14	14	0	Below Guideline
Escherichia Coli	02-Jan-19	0 per 100 mL	14	14	0	Below Guideline
Total Coliforms	08-Jan-19	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	08-Jan-19	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	09-Jan-19	0 per 100 mL	6	6	0	Below Guideline
Escherichia Coli	09-Jan-19	0 per 100 mL	6	6	0	Below Guideline
Total Coliforms	15-Jan-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	15-Jan-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	16-Jan-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	16-Jan-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	22-Jan-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	22-Jan-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	23-Jan-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	23-Jan-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	29-Jan-19	0 per 100 mL	6	6	0	Below Guideline
Escherichia Coli	29-Jan-19	0 per 100 mL	6	6	0	Below Guideline
Total Coliforms	30-Jan-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	30-Jan-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	05-Feb-19	0 per 100 mL	14	14	0	Below Guideline
Escherichia Coli	05-Feb-19	0 per 100 mL	14	14	0	Below Guideline
Total Coliforms	13-Feb-19	0 per 100 mL	14	14	0	Below Guideline
Escherichia Coli	13-Feb-19	0 per 100 mL	14	14	0	Below Guideline
Total Coliforms	19-Feb-19	0 per 100 mL	14	14	0	Below Guideline
Escherichia Coli	19-Feb-19	0 per 100 mL	14	14	0	Below Guideline
Total Coliforms	27-Feb-19	0 per 100 mL	14	14	0	Below Guideline
Escherichia Coli	27-Feb-19	0 per 100 mL	14	14	0	Below Guideline
Total Coliforms	08-Mar-19	0 per 100 mL	14	14	0	Below Guideline
Escherichia Coli	08-Mar-19	0 per 100 mL	14	14	0	Below Guideline
Total Coliforms	13-Mar-19	0 per 100 mL	14	14	0	Below Guideline
Escherichia Coli	13-Mar-19	0 per 100 mL	14	14	0	Below Guideline
Total Coliforms	19-Mar-19	0 per 100 mL	14	14	0	Below Guideline
Escherichia Coli	19-Mar-19	0 per 100 mL	14	14	0	Below Guideline
Total Coliforms	26-Mar-19	0 per 100 mL	14	14	0	Below Guideline
Escherichia Coli	26-Mar-19	0 per 100 mL	14	14	0	Below Guideline
Total Coliforms	02-Apr-19	0 per 100 mL	14	14	0	Below Guideline
Escherichia Coli	02-Apr-19	0 per 100 mL	14	14	0	Below Guideline
Total Coliforms	09-Apr-19	0 per 100 mL	14	14	0	Below Guideline
Escherichia Coli	09-Apr-19	0 per 100 mL	14	14	0	Below Guideline
Total Coliforms	16-Apr-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	16-Apr-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	17-Apr-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	17-Apr-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	24-Apr-19	0 per 100 mL	14	14	0	Below Guideline
Escherichia Coli	24-Apr-19	0 per 100 mL	14	14	0	Below Guideline
Total Coliforms	30-Apr-19	0 per 100 mL	10	10	0	Below Guideline
Escherichia Coli	30-Apr-19	0 per 100 mL	10	10	0	Below Guideline
Total Coliforms	01-May-19	0 per 100 mL	4	4	0	Below Guideline
Escherichia Coli	01-May-19	0 per 100 mL	4	4	0	Below Guideline
Total Coliforms	07-May-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	07-May-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	08-May-19	0 per 100 mL	6	6	0	Below Guideline
Escherichia Coli	08-May-19	0 per 100 mL	6	6	0	Below Guideline
Total Coliforms	14-May-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	14-May-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	15-May-19	0 per 100 mL	7	6	1	Above Guideline *
Escherichia Coli	15-May-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	21-May-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	21-May-19	0 per 100 mL	7	7	0	Below Guideline

Microbiological Analysis MPN / 100mL	Date	Guideline Limit 0 per 100 ml	# of Samples	Pass	Fail	Guideline Comments
Total Coliforms	22-May-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	22-May-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	27-May-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	27-May-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	28-May-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	28-May-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	03-Jun-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	03-Jun-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	04-Jun-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	04-Jun-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	10-Jun-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	10-Jun-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	11-Jun-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	11-Jun-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	17-Jun-19	0 per 100 mL	7	6	1	Above Guideline **
Escherichia Coli	17-Jun-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	18-Jun-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	18-Jun-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	24-Jun-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	24-Jun-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	25-Jun-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	25-Jun-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	02-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	02-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	03-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	03-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	08-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	08-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	09-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	09-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	16-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	16-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	17-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	17-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	22-Jul-19	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	22-Jul-19	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	23-Jul-19	0 per 100 mL	6	6	0	Below Guideline
Escherichia Coli	23-Jul-19	0 per 100 mL	6	6	0	Below Guideline
Total Coliforms	29-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	29-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	30-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	30-Jul-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	06-Aug-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	06-Aug-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	07-Aug-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	07-Aug-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	12-Aug-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	12-Aug-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	13-Aug-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	13-Aug-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	19-Aug-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	19-Aug-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	20-Aug-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	20-Aug-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	26-Aug-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	26-Aug-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	27-Aug-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	27-Aug-19	0 per 100 mL	7	7	0	Below Guideline

Microbiological Analysis MPN / 100mL	Date	Guideline Limit 0 per 100 ml	# of Samples	Pass	Fail	Guideline Comments
Escherichia Coli	18-Dec-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	23-Dec-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	23-Dec-19	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	30-Dec-19	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	30-Dec-19	0 per 100 mL	7	7	0	Below Guideline
TOTALS			1424	1422	2	

* May 15 Total Coliforms was retested on May 18, results showed no coliforms. Retesting results found on Non-Routine results

** Jun 17 Total Coliforms was retested on June 20, results showed no coliforms. Retesting results found on Non-Routine results