

Bacterial Results - 2020

Microbiological Analysis MPN / 100mL	Date	Guideline Limit 0 per 100 ml	# of Samples	Pass	Fail	Guideline Comments
Total Coliforms	06-Jan-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	06-Jan-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	07-Jan-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	07-Jan-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	13-Jan-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	13-Jan-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	14-Jan-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	14-Jan-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	21-Jan-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	21-Jan-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	22-Jan-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	22-Jan-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	28-Jan-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	28-Jan-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	03-Feb-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	03-Feb-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	04-Feb-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	04-Feb-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	11-Feb-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	11-Feb-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	18-Feb-20	0 per 100 mL	13	13	0	Below Guideline
Escherichia Coli	18-Feb-20	0 per 100 mL	13	13	0	Below Guideline
Total Coliforms	25-Feb-20	0 per 100 mL	13	13	0	Below Guideline
Escherichia Coli	25-Feb-20	0 per 100 mL	13	13	0	Below Guideline
Total Coliforms	03-Mar-20	0 per 100 mL	13	13	0	Below Guideline
Escherichia Coli	03-Mar-20	0 per 100 mL	13	13	0	Below Guideline
Total Coliforms	09-Mar-20	0 per 100 mL	13	13	0	Below Guideline
Escherichia Coli	09-Mar-20	0 per 100 mL	13	13	0	Below Guideline
Total Coliforms	16-Mar-20	0 per 100 mL	13	13	0	Below Guideline
Escherichia Coli	16-Mar-20	0 per 100 mL	13	13	0	Below Guideline
Total Coliforms	23-Mar-20	0 per 100 mL	6	6	0	Below Guideline
Escherichia Coli	23-Mar-20	0 per 100 mL	6	6	0	Below Guideline
Total Coliforms	24-Mar-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	24-Mar-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	30-Mar-20	0 per 100 mL	6	6	0	Below Guideline
Escherichia Coli	30-Mar-20	0 per 100 mL	6	6	0	Below Guideline
Total Coliforms	31-Mar-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	31-Mar-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	06-Apr-20	0 per 100 mL	6	6	0	Below Guideline
Escherichia Coli	06-Apr-20	0 per 100 mL	6	6	0	Below Guideline
Total Coliforms	07-Apr-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	07-Apr-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	14-Apr-20	0 per 100 mL	6	6	0	Below Guideline
Escherichia Coli	14-Apr-20	0 per 100 mL	6	6	0	Below Guideline
Total Coliforms	15-Apr-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	15-Apr-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	20-Apr-20	0 per 100 mL	6	6	0	Below Guideline
Escherichia Coli	20-Apr-20	0 per 100 mL	6	6	0	Below Guideline
Total Coliforms	21-Apr-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	21-Apr-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	27-Apr-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	27-Apr-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	28-Apr-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	28-Apr-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	04-May-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	04-May-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	05-May-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	05-May-20	0 per 100 mL	7	7	0	Below Guideline

Microbiological Analysis MPN / 100mL	Date	Guideline Limit 0 per 100 ml	# of Samples	Pass	Fail	Guideline Comments
Total Coliforms	11-May-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	11-May-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	12-May-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	12-May-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	19-May-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	19-May-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	20-May-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	20-May-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	25-May-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	25-May-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	26-May-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	26-May-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	01-Jun-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	01-Jun-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	02-Jun-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	02-Jun-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	08-Jun-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	08-Jun-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	15-Jun-20	0 per 100 mL	7	6	1	Above Guideline*
Escherichia Coli	15-Jun-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	16-Jun-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	16-Jun-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	22-Jun-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	22-Jun-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	23-Jun-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	23-Jun-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	29-Jun-20	0 per 100 mL	9	8	1	Above Guideline**
Escherichia Coli	29-Jun-20	0 per 100 mL	9	9	0	Below Guideline
Total Coliforms	06-Jul-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	06-Jul-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	07-Jul-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	07-Jul-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	13-Jul-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	13-Jul-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	14-Jul-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	14-Jul-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	20-Jul-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	20-Jul-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	21-Jul-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	21-Jul-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	27-Jul-20	0 per 100 mL	7	6	1	Above Guideline***
Escherichia Coli	27-Jul-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	28-Jul-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	28-Jul-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	04-Aug-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	04-Aug-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	05-Aug-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	05-Aug-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	10-Aug-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	10-Aug-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	11-Aug-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	11-Aug-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	17-Aug-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	17-Aug-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	18-Aug-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	18-Aug-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	24-Aug-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	24-Aug-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	25-Aug-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	25-Aug-20	0 per 100 mL	8	8	0	Below Guideline

Microbiological Analysis MPN / 100mL	Date	Guideline Limit 0 per 100 ml	# of Samples	Pass	Fail	Guideline Comments
Total Coliforms	03-Sep-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	03-Sep-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	05-Sep-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	05-Sep-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	09-Sep-20	0 per 100 mL	9	9	0	Below Guideline
Escherichia Coli	09-Sep-20	0 per 100 mL	9	9	0	Below Guideline
Total Coliforms	10-Sep-20	0 per 100 mL	6	6	0	Below Guideline
Escherichia Coli	10-Sep-20	0 per 100 mL	6	6	0	Below Guideline
Total Coliforms	14-Sep-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	14-Sep-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	15-Sep-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	15-Sep-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	21-Sep-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	21-Sep-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	22-Sep-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	22-Sep-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	28-Sep-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	28-Sep-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	29-Sep-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	29-Sep-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	05-Oct-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	05-Oct-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	06-Oct-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	06-Oct-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	29-Sep-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	13-Oct-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	13-Oct-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	13-Oct-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	13-Oct-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	19-Oct-20	0 per 100 mL	15	N/A	N/A	****
Escherichia Coli	19-Oct-20	0 per 100 mL	15	N/A	N/A	****
Total Coliforms	26-Oct-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	26-Oct-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	27-Oct-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	27-Oct-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	02-Nov-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	02-Nov-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	03-Nov-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	03-Nov-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	11-Nov-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	11-Nov-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	16-Nov-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	16-Nov-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	17-Nov-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	17-Nov-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	23-Nov-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	23-Nov-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	24-Nov-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	24-Nov-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	30-Nov-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	30-Nov-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	01-Dec-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	01-Dec-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	07-Dec-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	07-Dec-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	08-Dec-20	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	08-Dec-20	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	14-Dec-20	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	14-Dec-20	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	15-Dec-20	0 per 100 mL	8	8	0	Below Guideline

Microbiological Analysis MPN / 100mL	Date	Guideline Limit 0 per 100 ml	# of Samples	Pass	Fail	Guideline Comments
Escherichia Coli	15-Dec-20	0 per 100 mL	8	8	0	Below Guideline
TOTALS			1368	1335	3	

*June 15 - Unable to obtain Coliform count. Re-test on June 18 showed no coliforms. Re-test results located under "Non-Routine" report.

** June 29 - Unable to obtain Coliform count. Re-test on July 2 showed no coliforms. Re-test results located under "Non-Routine" report.

*** July 27 - Re-test on July 30 showed no coliforms. Re-test results located under "Non-Routine" report.

**** October 19 - Samples delayed at Fraser Health – transit time exceeded – testing rejected