

THM & HAA RESULTS 2020

Sample	Unit of Measure	Nominal Detection Limit	Sample Location				Sampled Date
			Marine Dr Station	Roper PRV	Stevens Station	Stayte Station	
Chloroform	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	21-Apr-20
Bromodichloromethane	mg/L	0.001	0.001	0.001	0.001	0.001	21-Apr-20
Dibromochloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	21-Apr-20
Bromoform	mg/L	0.001	<0.001	0.001	0.001	0.001	21-Apr-20
Total THMs	mg/L	0.001	0.001	0.002	0.002	0.002	21-Apr-20
Dibromofluoromethane	%	50-140	114	116	113	115	21-Apr-20
Toluene-d8	%	50-140	91	90	90	90	21-Apr-20
Bromofluorobenzene	%	50-140	91	91	92	92	21-Apr-20
Monochloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	21-Apr-20
Monobromoacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	21-Apr-20
Dichloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	21-Apr-20
Bromochloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	21-Apr-20
Dibromoacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	21-Apr-20
Trichloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	21-Apr-20
Total HAA6	ug/L	12.0	<12.0	<12.0	<12.0	<12.0	21-Apr-20
2,3-Dibromopropionic Acid	%	50-150	86	87	92	91	21-Apr-20

Sample	Unit of Measure	Nominal Detection Limit	Sample Location				Sampled Date
			Marine Dr Station	Roper PRV	Stevens Station	Stayte Station	
Chloroform	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	6-Jul-20
Bromodichloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	6-Jul-20
Dibromochloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	6-Jul-20
Bromoform	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	6-Jul-20
Total THMs	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	6-Jul-20
Dibromofluoromethane	%	50-140	99	101	98	97	6-Jul-20
Toluene-d8	%	50-140	101	102	100	100	6-Jul-20
Bromofluorobenzene	%	50-140	107	107	107	104	6-Jul-20
Monochloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	6-Jul-20
Monobromoacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	6-Jul-20
Dichloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	6-Jul-20
Bromochloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	6-Jul-20
Dibromoacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	6-Jul-20
Trichloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	6-Jul-20
Total HAA6	ug/L	12.0	<12.0	<12.0	<12.0	<12.0	6-Jul-20
2,3-Dibromopropionic Acid	%	50-150	100	130	110	110	6-Jul-20

Sample	Unit of Measure	Nominal Detection Limit	Sample Location				Sampled Date
			Marine Dr Station	Roper PRV	Stevens Station	Stayte Station	
Chloroform	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	19-Oct-20
Bromodichloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	19-Oct-20
Dibromochloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	19-Oct-20
Bromoform	mg/L	0.001	<0.001	<0.001	<0.001	0.001	19-Oct-20
Total THMs	mg/L	0.001	<0.001	<0.001	<0.001	0.001	19-Oct-20
Dibromofluoromethane	%	50-140	112	93	109	110	19-Oct-20
Toluene-d8	%	50-140	96	99	99	104	19-Oct-20
Bromofluorobenzene	%	50-140	101	106	104	110	19-Oct-20
Monochloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	19-Oct-20
Monobromoacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	19-Oct-20
Dichloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	19-Oct-20
Bromochloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	19-Oct-20
Dibromoacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	19-Oct-20
Trichloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	19-Oct-20
Total HAA6	ug/L	12.0	<12.0	<12.0	<12.0	<12.0	19-Oct-20
2,3-Dibromopropionic Acid	%	50-150	96	110	110	110	19-Oct-20