

## Oxford & Merklin Chlorination Metal Results 2018

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
<b>Nominal Detection Limit</b>		<b>0.0001</b>	<b>0.0005</b>	<b>0.00001</b>	<b>0.004</b>	<b>0.001</b>	<b>5</b>	
<b>Guideline Limit</b>		<b>0.01</b>	<b>1</b>	<b>0.01</b>	<b>0.3</b>	<b>0.05</b>		<b>6.5 - 8.5</b>
Everall Sample Station	02-Jan-18	0.0053	0.0011	0.00004	0.004	0.025	<5	7.90
Malabar Sample Station	02-Jan-18	0.0054	0.0030	0.00029	0.007	0.020	<5	7.95
Chestnut Sample Station	02-Jan-18	0.0053	0.0011	0.00007	0.016	0.022	<5	7.94
Russell Avenue Sample Station	02-Jan-18	0.0080	0.0009	0.000098	0.009	0.12	<5	8.03
Roper PRV	02-Jan-18	0.0078	0.0013	0.00007	0.011	0.11	<5	8.03
Roper Ave Station	03-Jan-18	0.0082	0.0023	0.00063	0.006	0.12	<5	8.00
Finlay Street Station	03-Jan-18	0.0072	0.0008	0.00005	<0.004	0.086	<5	7.99
Stayte Road Station	03-Jan-18	0.0072	0.0026	0.00031	0.008	0.080	<5	8.00
Balsam Station	03-Jan-18	0.0064	0.00099	0.00022	0.005	0.063	<5	7.97
Buena Vista Station	03-Jan-18	0.0070	0.0107	0.00048	0.010	0.092	<5	8.00
Everall Sample Station	09-Jan-18	0.0057	0.0013	0.00006	<0.004	0.021	<5	7.88
Mann Park Station	09-Jan-18	0.0057	0.0064	0.00024	0.008	0.021	<5	7.96
Marine Drive Station	09-Jan-18	0.0056	0.0029	0.00017	0.009	0.017	<5	7.99
Russell Avenue Sample Station	09-Jan-18	0.0086	0.0011	0.00010	<0.004	0.11	<5	8.05
Roper PRV	09-Jan-18	0.0080	0.0006	0.00005	0.004	0.10	<5	8.05
Stevens Station	10-Jan-18	0.0086	0.0027	0.00011	0.006	0.12	<5	8.07
Finlay Street Station	10-Jan-18	0.0084	0.0008	0.00005	0.008	0.11	<5	8.06
Stayte Road Station	10-Jan-18	0.0073	0.0038	0.00039	0.0097	0.075	<5	8.04
Balsam and Marine Station	10-Jan-18	0.0062	0.00097	0.00018	0.013	0.059	<5	8.00
Oxford & Buena Vista Station	10-Jan-18	0.0064	0.0012	0.00008	0.012	0.087	<5	8.00
Everall Sample Station	16-Jan-18	0.0055	0.0012	<0.00001	<0.004	0.023	<5	7.89
Malabar Sample Station	16-Jan-18	0.0056	0.0029	0.00013	0.008	0.023	<5	7.94
Chestnut Sample Station	16-Jan-18	0.0056	0.0008	<0.00001	0.009	0.023	<5	7.96
Russell Avenue Sample Station	16-Jan-18	0.0082	0.0009	<0.00001	0.008	0.11	<5	7.95
Roper PRV	16-Jan-18	0.0081	<0.0005	<0.00001	0.006	0.11	<5	8.02
Roper Station	16-Jan-18	0.0085	0.0023	0.00022	0.010	0.12	<5	8.00
Finlay Street Station	17-Jan-18	0.0070	0.0006	<0.00001	0.007	0.080	<5	7.84
Stayte Road Station	17-Jan-18	0.0071	0.0032	0.00027	0.009	0.079	<5	7.97
Balsam and Marine Station	17-Jan-18	0.0073	0.0008	0.00012	0.011	0.080	<5	8.02
Oxford & Buena Vista Station	17-Jan-18	0.0071	0.0009	0.00008	0.013	0.093	<5	8.02
Everall Sample Station	23-Jan-18	0.0053	0.0013	0.00004	<0.004	0.024	<5	7.96
Mann Park Station	23-Jan-18	0.0055	0.0062	0.00016	0.005	0.023	<5	7.98
Marine Drive Station	23-Jan-18	0.0053	0.0031	0.00011	0.011	0.023	<5	8.00
Russell Avenue Sample Station	23-Jan-18	0.0082	0.0020	0.00009	0.008	0.12	<5	8.09
Roper PRV	23-Jan-18	0.0077	0.0013	0.00004	0.007	0.10	<5	8.07
Stevens Station	23-Jan-18	0.0080	0.0025	0.00009	0.007	0.12	<5	8.09
Finlay Street Station	24-Jan-18	0.0095	0.00097	0.00004	0.007	0.096	<5	7.98
Stayte Road Station	24-Jan-18	0.0072	0.0023	0.00026	0.008	0.082	<5	8.01
Balsam and Marine Station	24-Jan-18	0.0062	0.0008	0.00019	0.011	0.061	<5	7.99
Oxford & Buena Vista Station	24-Jan-18	0.0069	0.0009	0.00007	0.010	0.089	<5	8.00
Everall Sample Station	30-Jan-18	0.0058	0.0008	0.00006	<0.004	0.025	<5	7.85
Malabar Sample Station	30-Jan-18	0.0058	0.0024	0.00189	0.009	0.022	<5	7.94
Chestnut Sample Station	30-Jan-18	0.0058	0.0006	0.00012	0.009	0.021	<5	7.96
Russell Avenue Sample Station	30-Jan-18	0.0088	0.0008	0.00012	0.004	0.12	<5	8.05
Roper PRV	30-Jan-18	0.0085	0.0007	0.00005	<0.004	0.11	<5	8.05
Roper Station	30-Jan-18	0.0089	0.0025	0.00030	0.006	0.12	<5	7.93
Finlay Street Station	31-Jan-18	0.0073	0.0008	0.00004	<0.004	0.093	<5	7.97
Stayte Road Station	31-Jan-18	0.0068	0.0024	0.00025	<0.004	0.077	<5	8.01
Balsam and Marine Station	31-Jan-18	0.0058	0.0012	0.00021	<0.004	0.054	<5	7.98
Oxford & Buena Vista Station	31-Jan-18	0.0058	0.0012	0.00008	<0.004	0.077	<5	7.98

## Oxford & Merklin Chlorination Metal Results 2018

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
<b>Nominal Detection Limit</b>		<b>0.0001</b>	<b>0.0005</b>	<b>0.00001</b>	<b>0.004</b>	<b>0.001</b>	<b>5</b>	
<b>Guideline Limit</b>		<b>0.01</b>	<b>1</b>	<b>0.01</b>	<b>0.3</b>	<b>0.05</b>		<b>6.5 - 8.5</b>
Everall Sample Station	06-Feb-18	0.0057	0.0006	0.00005	0.004	0.026	<5	7.91
Malabar Sample Station	06-Feb-18	0.0057	0.0027	0.00030	0.007	0.021	<5	7.98
Chestnut Sample Station	06-Feb-18	0.0057	0.0005	0.00009	0.009	0.022	<5	8.00
Russell Avenue Sample Station	06-Feb-18	0.0087	0.0009	0.00012	0.005	0.13	<5	8.09
Roper PRV	06-Feb-18	0.0082	0.0012	0.00008	0.004	0.11	<5	8.07
Roper Station	06-Feb-18	0.0086	0.0022	0.00031	0.008	0.13	<5	8.09
Finlay Street Station	06-Feb-18	0.0069	0.0008	0.00003	0.008	0.073	<5	8.10
Stayte Road Station	07-Feb-18	0.0071	0.0023	0.00025	0.009	0.074	<5	8.01
Balsam and Marine Station	07-Feb-18	0.0060	0.00096	0.00016	0.0097	0.055	<5	8.02
Oxford & Buena Vista Station	07-Feb-18	0.0077	0.0012	0.000095	0.012	0.10	<5	8.06
Everall Sample Station	13-Feb-18	0.0055	0.0008	0.00007	0.005	0.025	<5	7.79
Mann Park Station	13-Feb-18	0.0055	0.0057	0.00017	0.004	0.025	<5	7.90
Marine Drive Station	13-Feb-18	0.0055	0.0023	0.00015	0.008	0.025	<5	7.93
Russell Avenue Sample Station	13-Feb-18	0.0085	0.0008	0.00009	0.007	0.14	<5	8.01
Roper PRV	13-Feb-18	0.0079	0.0015	0.00008	0.007	0.12	<5	8.01
Stevens Station	13-Feb-18	0.0085	0.0022	0.00012	0.006	0.14	<5	8.02
Finlay Street Station	14-Feb-18	0.0077	0.0006	0.00004	0.004	0.096	<5	7.87
Stayte Road Station	14-Feb-18	0.0072	0.0020	0.00024	0.005	0.077	<5	8.00
Balsam and Marine Station	14-Feb-18	0.0059	0.0009	0.00016	<0.004	0.053	<5	7.88
Oxford & Buena Vista Station	14-Feb-18	0.0068	0.0008	0.00008	0.007	0.089	<5	8.00
Everall Sample Station	20-Feb-18	0.0054	0.0016	0.00006	0.007	0.026	<5	7.72
Malabar Sample Station	20-Feb-18	0.0054	0.0030	0.00024	0.008	0.021	<5	7.86
Chestnut Sample Station	20-Feb-18	0.0054	0.0011	0.00016	0.013	0.022	<5	7.88
Russell Avenue Sample Station	20-Feb-18	0.0068	0.00099	0.00009	0.005	0.079	<5	7.93
Roper PRV	20-Feb-18	0.079	<0.0005	0.00004	0.006	0.12	<5	7.97
Roper Station	20-Feb-18	0.0082	0.0019	0.00029	0.009	0.13	<5	7.99
Finlay Street Station	20-Feb-18	0.0069	0.0017	0.00005	0.008	0.082	<5	7.95
Stayte Road Station	21-Feb-18	0.0076	0.0034	0.00035	0.009	0.086	<5	7.81
Balsam and Marine Station	21-Feb-18	0.0069	0.0013	0.00021	0.008	0.071	<5	7.86
Oxford & Buena Vista Station	21-Feb-18	0.0079	0.0012	0.000095	0.011	0.11	<5	7.95
Everall Sample Station	27-Feb-18	0.0061	0.0009	0.00006	<0.004	0.036	<5	7.81
Mann Park Station	27-Feb-18	0.0059	0.0057	0.00022	<0.004	0.030	<5	7.93
Marine Drive Station	27-Feb-18	0.0059	0.0029	0.00014	0.007	0.023	<5	7.96
Russell Avenue Sample Station	27-Feb-18	0.0086	0.0011	0.00009	0.004	0.12	<5	7.94
Roper PRV	27-Feb-18	0.0083	0.0005	0.00004	0.004	0.11	<5	8.03
Stevens Station	27-Feb-18	0.0072	0.0024	0.00011	<0.004	0.083	<5	8.01
Finlay Street Station	28-Feb-18	0.0079	0.0025	0.00006	0.008	0.11	<5	7.89
Stayte Road Station	28-Feb-18	0.0074	0.0029	0.00024	0.008	0.087	<5	7.98
Balsam and Marine Station	28-Feb-18	0.0068	0.0013	0.00020	0.007	0.075	<5	8.00
Oxford & Buena Vista Station	28-Feb-18	0.0069	0.0012	0.000097	0.011	0.10	<5	7.99
Everall Sample Station	06-Mar-18	0.0065	0.0010	0.00012	0.004	0.039	<5	7.73
Malabar Sample Station	06-Mar-18	0.0063	0.0028	0.00024	0.012	0.030	<5	7.89
Chestnut Sample Station	06-Mar-18	0.0062	0.0012	0.00010	0.009	0.026	<5	7.94
Russell Avenue Sample Station	06-Mar-18	0.0078	0.0012	0.00009	0.004	0.093	<5	7.98
Roper PRV	06-Mar-18	0.0084	0.0008	0.00005	0.005	0.11	<5	8.01
Roper Station	06-Mar-18	0.0089	0.0036	0.00040	0.008	0.13	<5	8.01
Finlay Street Station	06-Mar-18	0.0085	0.00096	0.00006	0.006	0.12	<5	8.01
Stayte Road Station	06-Mar-18	0.0078	0.0030	0.00023	0.008	0.086	<5	7.99
Balsam and Marine Station	06-Mar-18	0.0064	0.0012	0.00019	0.008	0.060	<5	7.94
Oxford & Buena Vista Station	06-Mar-18	0.0070	0.0012	0.00011	0.010	0.095	<5	7.97
Everall Sample Station	13-Mar-18	0.0061	0.0008	0.00011	0.007	0.042	<5	7.86
Mann Park Station	13-Mar-18	0.0060	0.0057	0.00017	0.004	0.029	<5	7.97
Marine Drive Station	13-Mar-18	0.0060	0.0025	0.00019	0.012	0.026	<5	8.00
Russell Avenue Sample Station	13-Mar-18	0.0087	0.0010	0.000096	0.006	0.13	<5	8.08
Roper PRV	13-Mar-18	0.0086	0.0007	0.00003	0.005	0.12	<5	8.09
Stevens Station	13-Mar-18	0.0074	0.0027	0.00017	0.006	0.097	<5	8.06

## Oxford & Merklin Chlorination Metal Results 2018

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
<b>Nominal Detection Limit</b>		<b>0.0001</b>	<b>0.0005</b>	<b>0.00001</b>	<b>0.004</b>	<b>0.001</b>	<b>5</b>	
<b>Guideline Limit</b>		<b>0.01</b>	<b>1</b>	<b>0.01</b>	<b>0.3</b>	<b>0.05</b>		<b>6.5 - 8.5</b>
Finlay Street Station	14-Mar-18	0.0084	0.00095	0.00005	<0.004	0.11	<5	7.83
Stayte Road Station	14-Mar-18	0.0076	0.0029	0.00023	0.004	0.081	<5	7.95
Balsam and Marine Station	14-Mar-18	0.0066	0.0012	0.00022	0.006	0.066	<5	7.95
Oxford & Buena Vista Station	14-Mar-18	0.0066	0.0010	0.00007	0.007	0.092	<5	7.97
Everall Sample Station	20-Mar-18	0.0058	0.0010	0.00012	0.004	0.035	<5	7.83
Malabar Sample Station	20-Mar-18	0.0058	0.0025	0.00021	0.009	0.027	<5	7.94
Chestnut Sample Station	20-Mar-18	0.0058	0.0013	0.00011	0.010	0.026	<5	7.97
Russell Avenue Sample Station	20-Mar-18	0.0059	0.0011	0.000097	<0.004	0.032	<5	7.98
Roper PRV	20-Mar-18	0.0075	0.0009	0.00004	0.005	0.088	<5	8.03
Roper Ave Station	20-Mar-18	0.0085	0.0027	0.00029	0.008	0.12	<5	8.08
Finlay Street Station	20-Mar-18	0.0069	0.0013	0.00005	0.006	0.074	<5	8.03
Stayte Road Station	20-Mar-18	0.0067	0.0032	0.00024	0.007	0.068	<5	8.03
Balsam and Marine Station	20-Mar-18	0.0061	0.0012	0.00024	0.008	0.052	<5	8.00
Oxford & Buena Vista Station	20-Mar-18	0.0061	0.0011	0.00009	0.009	0.072	<5	8.04
Everall Sample Station	27-Mar-18	0.0058	0.0009	0.00013	<0.004	0.033	<5	7.78
Mann Park Station	27-Mar-18	0.0056	0.0054	0.00019	<0.004	0.025	<5	8.15
Marine Drive Station	27-Mar-18	0.0056	0.0021	0.00013	0.007	0.024	<5	8.18
Russell Avenue Sample Station	27-Mar-18	0.0058	0.0010	0.00011	<0.004	0.030	<5	8.24
Roper Reservoir	27-Mar-18	0.0070	0.00099	0.00006	0.007	0.072	<5	8.29
Roper PRV	27-Mar-18	0.0076	0.0011	0.00005	0.006	0.091	<5	8.31
Stevens Station	27-Mar-18	0.0083	0.0023	0.00013	0.004	0.11	<5	8.33
Finlay Street Station	27-Mar-18	0.0064	0.0009	0.00006	0.006	0.058	<5	8.29
Stayte Road Station	28-Mar-18	0.0066	0.0028	0.00023	0.006	0.061	<5	8.08
Balsam and Marine Station	28-Mar-18	0.0057	0.0013	0.00030	0.008	0.073	<5	8.04
Oxford & Buena Vista Station	28-Mar-18	0.0058	0.0011	0.00012	0.008	0.084	<5	8.17
Everall Sample Station	04-Apr-18	0.0061	0.0014	0.00014	<0.004	0.13	<5	7.75
Mann Park Station	04-Apr-18	0.0061	0.0048	0.00018	0.004	0.11	<5	7.89
Marine Drive Station	04-Apr-18	0.0062	0.0026	0.00018	0.009	0.076	<5	7.93
Russell Avenue Sample Station	04-Apr-18	0.0089	0.0008	0.00012	0.007	0.14	<5	8.02
Roper PRV	04-Apr-18	0.0085	0.0027	0.00026	0.005	0.14	<5	8.03
Stevens Station	04-Apr-18	0.0076	0.0023	0.00014	0.006	0.13	<5	8.03
Finlay Street Station	04-Apr-18	0.0073	0.0007	0.00005	0.006	0.13	<5	8.02
Stayte Road Station	04-Apr-18	0.0077	0.0023	0.00028	0.011	0.12	<5	8.02
Balsam and Marine Station	04-Apr-18	0.0078	0.0010	0.00027	0.007	0.13	<5	8.02
Oxford & Buena Vista Station	04-Apr-18	0.0071	0.0065	0.00032	0.011	0.13	<5	8.01
Everall Sample Station	24-Apr-18	0.0056	0.0011	0.00012	<0.004	0.033	<5	7.76
Malabar Sample Station	24-Apr-18	0.0058	0.0025	0.00028	0.009	0.053	<5	7.91
Chestnut Sample Station	24-Apr-18	0.0058	0.0013	0.00011	0.009	0.068	<5	7.96
Russell Avenue Sample Station	24-Apr-18	0.0087	0.0008	0.00011	0.005	0.13	<5	8.05
Roper PRV	24-Apr-18	0.0088	0.0007	0.00007	0.005	0.13	<5	8.07
Roper Ave Station	24-Apr-18	0.0087	0.0033	0.00043	0.006	0.13	<5	8.08
Finlay Street Station	24-Apr-18	0.0086	0.0009	0.00008	0.006	0.13	<5	8.08
Stayte Road Station	24-Apr-18	0.0079	0.0029	0.00030	0.0098	0.12	<5	7.90
Balsam and Marine Station	24-Apr-18	0.0081	0.0010	0.00028	0.009	0.11	<5	8.00
Oxford & Buena Vista Station	24-Apr-18	0.0077	0.0008	0.00010	0.011	0.13	<5	8.02
Everall Sample Station	08-May-18	0.0058	0.0015	<0.00001	0.005	0.052	<5	7.80
Mann Park Station	08-May-18	0.0058	0.0064	0.00015	0.004	0.045	<5	7.91
Marine Drive Station	08-May-18	0.0058	0.0036	0.00011	0.006	0.042	<5	7.94
Russell Avenue Sample Station	08-May-18	0.0087	0.0011	0.00002	0.006	0.14	<5	8.04
Roper PRV	08-May-18	0.0086	0.0008	<0.00001	0.005	0.14	<5	8.07
Stevens Station	08-May-18	0.0086	0.0025	0.00008	0.008	0.14	<5	8.08
Finlay Street Station	08-May-18	0.0085	0.0008	<0.00001	0.008	0.14	<5	8.08
Stayte Road Station	08-May-18	0.0076	0.0033	0.00024	0.008	0.11	<5	8.05
Balsam and Marine Station	08-May-18	0.0075	0.0012	0.00024	0.008	0.10	<5	8.05
Oxford & Buena Vista Station	08-May-18	0.0065	0.0009	0.00003	0.008	0.12	<5	8.03

## Oxford & Merklin Chlorination Metal Results 2018

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
<b>Nominal Detection Limit</b>		<b>0.0001</b>	<b>0.0005</b>	<b>0.00001</b>	<b>0.004</b>	<b>0.001</b>	<b>5</b>	
<b>Guideline Limit</b>		<b>0.01</b>	<b>1</b>	<b>0.01</b>	<b>0.3</b>	<b>0.05</b>		<b>6.5 - 8.5</b>
Everall Sample Station	22-May-18	0.0056	0.0018	0.00010	<0.004	0.068	<5	7.96
Malabar Sample Station	22-May-18	0.0054	0.0031	0.00039	0.007	0.049	<5	7.95
Chestnut Sample Station	22-May-18	0.0055	0.0013	0.00013	0.009	0.046	<5	7.96
Russell Avenue Sample Station	22-May-18	0.0084	0.0011	0.00011	0.007	0.14	<5	8.05
Roper PRV	22-May-18	0.0084	0.0007	0.00005	0.006	0.14	<5	8.06
Roper Ave Station	22-May-18	0.0084	0.0048	0.00063	0.007	0.14	<5	8.07
Finlay Street Station	23-May-18	0.0084	0.0009	0.00006	0.006	0.13	<5	7.84
Stayte Road Station	23-May-18	0.0072	0.0028	0.00031	0.010	0.11	<5	7.96
Balsam and Marine Station	23-May-18	0.0079	0.0009	0.00028	0.007	0.11	<5	8.02
Oxford & Buena Vista Station	23-May-18	0.0071	0.0008	0.00009	0.007	0.12	<5	8.02
Everall Sample Station	05-Jun-18	0.0056	0.0015	0.00010	<0.004	0.049	<5	7.80
Malabar Sample Station	05-Jun-18	0.0055	0.0065	0.00027	<0.004	0.042	<5	7.92
Chestnut Sample Station	05-Jun-18	0.0056	0.0039	0.00029	0.013	0.042	<5	7.96
Russell Avenue Sample Station	05-Jun-18	0.0085	0.0012	0.00012	0.005	0.14	<5	8.05
Roper PRV	05-Jun-18	0.0085	<0.0005	0.00005	0.004	0.14	<5	8.07
Roper Ave Station	05-Jun-18	0.0086	0.0028	0.00019	0.005	0.14	<5	8.08
Finlay Street Station	05-Jun-18	0.0083	0.0008	0.00008	0.006	0.14	<5	8.09
Stayte Road Station	05-Jun-18	0.0071	0.0037	0.00042	0.006	0.095	<5	8.05
Balsam and Marine Station	05-Jun-18	0.0077	0.0008	0.00037	0.008	0.11	<5	8.06
Oxford & Buena Vista Station	05-Jun-18	0.0070	0.0009	0.00018	0.008	0.11	<5	8.04
Everall Sample Station	26-Jun-18	0.0055	0.0012	0.00009	<0.004	0.053	<5	7.78
Malabar Sample Station	26-Jun-18	0.0055	0.0029	0.00035	0.005	0.040	<5	7.88
Chestnut Sample Station	26-Jun-18	0.0055	0.0014	0.00013	0.006	0.050	<5	7.95
Russell Avenue Sample Station	26-Jun-18	0.0084	0.0012	0.00011	0.006	0.13	<5	8.08
Roper PRV	26-Jun-18	0.0082	0.0005	0.00008	0.006	0.13	<5	8.11
Roper Ave Station	26-Jun-18	0.0083	0.0028	0.00045	0.005	0.14	<5	7.97
Finlay Street Station	26-Jun-18	0.0082	0.0008	0.00007	0.006	0.14	<5	8.09
Stayte Road Station	27-Jun-18	0.0067	0.0030	0.00035	0.006	0.092	<5	7.89
Balsam and Marine Station	27-Jun-18	0.0080	0.0010	0.00031	0.007	0.11	<5	8.10
Oxford & Buena Vista Station	27-Jun-18	0.0074	0.0009	0.00014	0.006	0.11	<5	8.15
Everall Sample Station	24-Jul-18	0.0059	0.0013	0.00001	<0.04	0.071	<5	7.77
Mann Park Station	24-Jul-18	0.0059	0.0066	0.00012	<0.04	0.072	<5	7.87
Marine Drive Station	24-Jul-18	0.0059	0.0051	0.00029	<0.004	0.064	<5	7.95
Russell Avenue Sample Station	24-Jul-18	0.0085	0.0011	0.00002	<0.004	0.13	<5	8.04
Roper PRV	24-Jul-18	0.0085	0.0016	0.00001	0.004	0.13	<5	7.86
Stevens Station	24-Jul-18	0.0086	0.0031	0.00017	0.004	0.13	<5	8.01
Finlay Street Station	24-Jul-18	0.0085	0.0008	<0.00001	<0.004	0.13	<5	8.06
Stayte Road Station	24-Jul-18	0.0069	0.0031	0.00032	0.004	0.100	<5	8.04
Balsam and Marine Station	25-Jul-18	0.0080	0.0011	0.00023	0.005	0.12	<5	7.77
Oxford & Buena Vista Station	25-Jul-18	0.0079	0.0008	0.00012	<0.004	0.093	<5	8.05
Finlay Street Station	29-Aug-18	0.0082	0.0008	0.00009	0.005	0.13	<5	7.91
Stayte Road Station	29-Aug-18	0.0070	0.0034	0.00042	<0.004	0.13	<5	8.07
Balsam and Marine Station	29-Aug-18	0.0079	0.0008	0.00020	<0.004	0.14	<5	8.12
Oxford & Buena Vista Station	29-Aug-18	0.0072	0.0012	0.00009	0.006	0.15	<5	8.11
Everall Sample Station	28-Aug-18	0.0065	0.0015	0.00008	<0.004	0.16	<5	7.95
Malabar Sample Station	28-Aug-18	0.0066	0.0025	0.00035	<0.004	0.15	<5	8.07
Chestnut Sample Station	28-Aug-18	0.0065	0.0010	0.00012	0.006	0.10	<5	8.08
Russell Avenue Sample Station	28-Aug-18	0.0065	0.0010	0.00009	<0.004	0.15	<5	8.11
Roper Reservoir	28-Aug-18	0.0075	0.0014	0.00007	<0.004	0.13	<5	8.14
Roper PRV	28-Aug-18	0.0078	0.0007	0.00006	<0.004	0.13	<5	8.15
Roper Ave Station	28-Aug-18	0.0080	0.0035	0.00065	<0.004	0.13	<5	8.16
Everall Sample Station	25-Sep-18	0.0060	0.0010	0.00006	0.004	0.12	<5	8.11
Malabar Sample Station	25-Sep-18	0.0060	0.0024	0.00032	0.005	0.11	<5	8.09
Chestnut Sample Station	25-Sep-18	0.0061	0.0006	0.00006	0.008	0.10	<5	8.09
Russell Avenue Sample Station	25-Sep-18	0.0059	0.0008	0.00007	0.004	0.11	<5	8.10
Roper PRV	25-Sep-18	0.0072	0.0008	0.00004	0.008	0.12	<5	8.14
Roper Ave Station	25-Sep-18	0.0076	0.0031	0.00045	0.006	0.12	<5	8.16

## Oxford & Merklin Chlorination Metal Results 2018

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
<b>Nominal Detection Limit</b>		<b>0.0001</b>	<b>0.0005</b>	<b>0.00001</b>	<b>0.004</b>	<b>0.001</b>	<b>5</b>	
<b>Guideline Limit</b>		<b>0.01</b>	<b>1</b>	<b>0.01</b>	<b>0.3</b>	<b>0.05</b>		<b>6.5 - 8.5</b>
Finlay Street Station	26-Sep-18	0.0080	0.0006	0.00007	0.009	0.12	<5	8.01
Stayte Road Station	26-Sep-18	0.0062	0.0026	0.00031	0.007	0.12	<5	8.10
Balsam and Marine Station	26-Sep-18	0.0063	0.0010	0.00019	0.007	0.12	<5	8.14
Oxford & Buena Vista Station	26-Sep-18	0.0063	0.0011	0.00006	0.007	0.12	<5	8.16
Everall Sample Station	27-Nov-18	0.0053	0.0010	0.00007	<0.004	0.086	<5	8.02
Mann Park Station	27-Nov-18	0.0051	0.0037	0.00010	<0.004	0.084	<5	8.13
Marine Drive Station	27-Nov-18	0.0051	0.0034	0.00021	<0.004	0.077	<5	8.16
Russell Avenue Sample Station	27-Nov-18	0.0065	0.0008	0.00008	<0.004	0.10	<5	8.19
Roper Reservoir	27-Nov-18	0.0074	0.0013	0.00004	0.007	0.12	<5	8.23
Roper PRV	27-Nov-18	0.0083	0.0007	0.00002	0.007	0.13	<5	8.24
Stevens Station	27-Nov-18	0.0080	0.0022	0.00012	<0.004	0.13	<5	8.23
Finlay Street Station	28-Nov-18	0.0083	0.0006	0.00007	<0.004	0.13	<5	8.08
Stayte Road Station	28-Nov-18	0.0062	0.0030	0.00026	0.007	0.11	<5	8.13
Balsam and Marine Station	28-Nov-18	0.0056	0.0013	0.00020	<0.004	0.10	<5	8.16
Oxford & Buena Vista Station	28-Nov-18	0.0061	0.0088	0.00031	<0.004	0.10	<5	8.18
Merklin Low Reservoir	28-Nov-18	0.0083	0.0276	0.00008	<0.004	0.14	<5	8.24
Merklin New Reservoir	28-Nov-18	0.0083	<0.0005	0.00004	<0.004	0.13	<5	8.25
Oxford Reservoir	28-Nov-18	0.0052	0.0100	0.00012	0.005	0.091	<5	8.03
Everall Sample Station	27-Dec-18	0.0053	0.0011	0.00005	<0.004	0.075	<5	7.93
Mann Park Station	27-Dec-18	0.0054	0.0033	0.00008	<0.004	0.078	<5	8.04
Marine Drive Station	27-Dec-18	0.0053	0.0033	0.00017	<0.004	0.075	<5	8.06
Russell Avenue Sample Station	27-Dec-18	0.0083	0.0008	0.00009	<0.004	0.13	<5	8.15
Roper Reservoir	27-Dec-18	0.0073	0.0017	0.00005	<0.004	0.11	<5	8.15
Roper PRV	27-Dec-18	0.0083	0.0010	0.00004	0.005	0.13	<5	8.17
Stevens Station	27-Dec-18	0.0082	0.0024	0.00013	0.005	0.13	<5	8.18
Finlay Street Station	28-Dec-18	0.0085	0.0006	0.00005	0.005	0.13	<5	8.09
Stayte Road Station	28-Dec-18	0.0069	0.0033	0.00024	0.007	0.097	<5	8.10
Balsam and Marine Station	28-Dec-18	0.0059	0.0016	0.00010	<0.004	0.072	<5	8.09
Oxford & Buena Vista Station	28-Dec-18	0.0063	0.0010	0.00005	0.004	0.082	<5	8.11
Merklin Low Reservoir	28-Dec-18	0.0086	0.0323	0.00013	0.004	0.13	<5	8.18
Merklin New Reservoir	28-Dec-18	0.0085	<0.0005	0.00001	<0.004	0.13	<5	8.18
Oxford Reservoir	28-Dec-18	0.0056	0.0090	0.00013	<0.004	0.031	<5	7.99