

Microbiological Results 2017

Date	Microbiological Analysis MPN / 100mL	Guideline Limit	# of Samples	Pass	Fail	Guideline Comments
Jan 05	Total Coliforms	0 per 100 mL	12	12	0	Below MAC
	Escherichia Coli	0 per 100 mL	12	12	0	Below MAC
Jan 10 & Jan 11	Total Coliforms	0 per 100 mL	8	8	0	Below MAC
	Escherichia Coli	0 per 100 mL	8	8	0	Below MAC
Jan 21 & Jan 24	Total Coliforms	0 per 100 mL	16	16	0	Below MAC
	Escherichia Coli	0 per 100 mL	16	16	0	Below MAC
Jan 31	Total Coliforms	0 per 100 mL	8	8	0	Below MAC
	Escherichia Coli	0 per 100 mL	8	8	0	Below MAC
Feb 7	Total Coliforms	0 per 100 mL	8	8	0	Below MAC
	Escherichia Coli	0 per 100 mL	8	8	0	Below MAC
Feb 14	Total Coliforms	0 per 100 mL	8	8	0	Below MAC
	Escherichia Coli	0 per 100 mL	8	8	0	Below MAC
Feb 21 & Feb 22	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Feb 28	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Mar 7	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Mar 17	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Mar 24	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Mar 29	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC

Microbiological Results 2017

Date	Microbiological Analysis MPN / 100mL	Guideline Limit	# of Samples	Pass	Fail	Guideline Comments
Apr 5	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Apr 11	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Apr 18	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Apr 25	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
May 2	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
May 9	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
May 16	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
May 23	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
May 30	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Jun 7	Total Coliforms	0 per 100 mL	11	11	0	Below MAC
	Escherichia Coli	0 per 100 mL	11	11	0	Below MAC
Jun 13	Total Coliforms	0 per 100 mL	6	6	0	Below MAC
	Escherichia Coli	0 per 100 mL	6	6	0	Below MAC
Jun 14	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Jun 21	Total Coliforms	0 per 100 mL	13	13	0	Below MAC
	Escherichia Coli	0 per 100 mL	13	13	0	Below MAC

Microbiological Results 2017

Date	Microbiological Analysis MPN / 100mL	Guideline Limit	# of Samples	Pass	Fail	Guideline Comments
Jun 27	Total Coliforms	0 per 100 mL	12	12	0	Below MAC
	Escherichia Coli	0 per 100 mL	12	12	0	Below MAC
Jul 5	Total Coliforms	0 per 100 mL	12	12	0	Below MAC
	Escherichia Coli	0 per 100 mL	12	12	0	Below MAC
Jul 11	Total Coliforms	0 per 100 mL	5	5	0	Below MAC
	Escherichia Coli	0 per 100 mL	5	5	0	Below MAC
Jul 12	Total Coliforms	0 per 100 mL	8	8	0	Below MAC
	Escherichia Coli	0 per 100 mL	8	8	0	Below MAC
Jul 18	Total Coliforms	0 per 100 mL	6	6	0	Below MAC
	Escherichia Coli	0 per 100 mL	6	6	0	Below MAC
Jul 19	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Jul 25	Total Coliforms	0 per 100 mL	13	13	0	Below MAC
	Escherichia Coli	0 per 100 mL	13	13	0	Below MAC
Aug 1	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Aug 2	Total Coliforms	0 per 100 mL	6	6	0	Below MAC
	Escherichia Coli	0 per 100 mL	6	6	0	Below MAC
*Aug 8	Total Coliforms	0 per 100 mL	7	6	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Aug 9	Total Coliforms	0 per 100 mL	6	6	0	Below MAC
	Escherichia Coli	0 per 100 mL	6	6	0	Below MAC
Aug 15	Total Coliforms	0 per 100 mL	13	13	0	Below MAC
	Escherichia Coli	0 per 100 mL	13	13	0	Below MAC
Aug 22	Total Coliforms	0 per 100 mL	13	13	0	Below MAC
	Escherichia Coli	0 per 100 mL	13	13	0	Below MAC

Microbiological Results 2017

Date	Microbiological Analysis MPN / 100mL	Guideline Limit	# of Samples	Pass	Fail	Guideline Comments
Aug 29	Total Coliforms	0 per 100 mL	6	6	0	Below MAC
	Escherichia Coli	0 per 100 mL	6	6	0	Below MAC
Aug 30	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Sep 5	Total Coliforms	0 per 100 mL	6	6	0	Below MAC
	Escherichia Coli	0 per 100 mL	6	6	0	Below MAC
Sep 6	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Sep 12	Total Coliforms	0 per 100 mL	13	13	0	Below MAC
	Escherichia Coli	0 per 100 mL	13	13	0	Below MAC
Sep 19	Total Coliforms	0 per 100 mL	8	8	0	Below MAC
	Escherichia Coli	0 per 100 mL	8	8	0	Below MAC
Sep 20	Total Coliforms	0 per 100 mL	5	5	0	Below MAC
	Escherichia Coli	0 per 100 mL	5	5	0	Below MAC
Sep 26	Total Coliforms	0 per 100 mL	13	13	0	Below MAC
	Escherichia Coli	0 per 100 mL	13	13	0	Below MAC
Oct 3	Total Coliforms	0 per 100 mL	5	5	0	Below MAC
	Escherichia Coli	0 per 100 mL	5	5	0	Below MAC
Oct 4	Total Coliforms	0 per 100 mL	8	8	0	Below MAC
	Escherichia Coli	0 per 100 mL	8	8	0	Below MAC
Oct 10	Total Coliforms	0 per 100 mL	8	8	0	Below MAC
	Escherichia Coli	0 per 100 mL	8	8	0	Below MAC
Oct 14	Total Coliforms	0 per 100 mL	5	5	0	Below MAC
	Escherichia Coli	0 per 100 mL	5	5	0	Below MAC
Oct 18	Total Coliforms	0 per 100 mL	11	11	0	Below MAC
	Escherichia Coli	0 per 100 mL	11	11	0	Below MAC

Microbiological Results 2017

Date	Microbiological Analysis MPN / 100mL	Guideline Limit	# of Samples	Pass	Fail	Guideline Comments
Oct 24	Total Coliforms	0 per 100 mL	10	10	0	Below MAC
	Escherichia Coli	0 per 100 mL	10	10	0	Below MAC
Oct 31	Total Coliforms	0 per 100 mL	13	13	0	Below MAC
	Escherichia Coli	0 per 100 mL	13	13	0	Below MAC
Nov 7	Total Coliforms	0 per 100 mL	13	13	0	Below MAC
	Escherichia Coli	0 per 100 mL	13	13	0	Below MAC
Nov 14	Total Coliforms	0 per 100 mL	13	13	0	Below MAC
	Escherichia Coli	0 per 100 mL	13	13	0	Below MAC
Nov 21	Total Coliforms	0 per 100 mL	4	4	0	Below MAC
	Escherichia Coli	0 per 100 mL	4	4	0	Below MAC
Nov 22	Total Coliforms	0 per 100 mL	6	6	0	Below MAC
	Escherichia Coli	0 per 100 mL	6	6	0	Below MAC
Nov 28	Total Coliforms	0 per 100 mL	6	6	0	Below MAC
	Escherichia Coli	0 per 100 mL	6	6	0	Below MAC
Nov 29	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC
Dec 5	Total Coliforms	0 per 100 mL	5	5	0	Below MAC
	Escherichia Coli	0 per 100 mL	5	5	0	Below MAC
Dec 6	Total Coliforms	0 per 100 mL	8	8	0	Below MAC
	Escherichia Coli	0 per 100 mL	8	8	0	Below MAC
*Dec 12	Total Coliforms	0 per 100 mL	7	6	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	6	0	Below MAC
Dec 13	Total Coliforms	0 per 100 mL	5	5	0	Below MAC
	Escherichia Coli	0 per 100 mL	5	5	0	Below MAC
Dec 19	Total Coliforms	0 per 100 mL	7	7	0	Below MAC
	Escherichia Coli	0 per 100 mL	7	7	0	Below MAC

Microbiological Results 2017

Date	Microbiological Analysis MPN / 100mL	Guideline Limit	# of Samples	Pass	Fail	Guideline Comments
Dec 20	Total Coliforms	0 per 100 mL	6	6	0	Below MAC
	Escherichia Coli	0 per 100 mL	6	6	0	Below MAC

*Aug 8 - 1 sample retested on Aug 11

*Dec 12 - 1 sample not tested, too long in transit