

Oxford & Merklin Chlorination Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001	5	
Guideline Limit		0.0100	1	0.01	0.3	0.05		6.5 - 8.5
Everall Sample Station	10-Jan-17	0.0063	0.0020	0.000093	<0.004	0.122	<5	7.78
Mann Park Sample Station	10-Jan-17	0.0066	0.0073	0.000363	<0.004	0.080	<5	7.87
Malabar Sample Station	10-Jan-17	0.0062	0.0035	0.000471	<0.004	0.053	<5	7.89
Marine Drive Sample Station	10-Jan-17	0.0064	0.0052	0.000404	<0.004	0.04	<5	7.93
Russell Avenue Sample Station	10-Jan-17	0.0066	0.0026	0.000166	<0.004	0.116	<5	7.92
Finlay Sampling Station	13-Jan-17	0.0059	0.0027	0.000130	0.208	0.083	<5	7.64
Roper PRV - High Zone	13-Jan-17	0.0064	0.001	0.000023	<0.004	0.114	<5	7.77
Kent St Activity Centre	13-Jan-17	0.0067	0.0049	0.000028	<0.004	0.092	<5	7.80
Stevens Sampling Station	13-Jan-17	0.0065	0.0020	0.000127	<0.004	0.090	<5	7.83
Roper Sampling Station	13-Jan-17	0.0077	0.0019	0.000274	<0.004	0.103	<5	7.88
Everall Sample Station	18-Jan-17	0.0059	0.0011	0.000063	<0.004	0.108	<5	7.78
Mann Park Sample Station	18-Jan-17	0.0056	0.0050	0.000315	<0.004	0.054	<5	7.81
Malabar Sample Station	18-Jan-17	0.0056	0.0021	0.000195	<0.004	0.041	<5	7.81
Marine Drive Sample Station	18-Jan-17	0.0056	0.0026	0.000222	<0.004	0.027	<5	7.81
Russell Avenue Sample Station	18-Jan-17	0.0057	0.0029	0.000188	<0.004	0.078	<5	7.84
Stevens Sampling Station	23-Jan-17	0.0086	0.0019	0.000159	0.009	0.121	<5	7.69
Roper Sampling Station	23-Jan-17	0.0086	0.0023	0.000324	0.008	0.116	<5	7.82
Roper PRV - High Zone	23-Jan-17	0.0067	0.0009	0.000029	<0.004	0.085	<5	7.81
Finlay Sampling Station	23-Jan-17	0.0071	0.0041	0.000124	0.005	0.085	<5	7.81
Kent St Activity Centre	23-Jan-17	0.0085	0.0061	0.000048	0.007	0.144	<5	7.85
Everall Sample Station	24-Jan-17	0.0057	0.0013	0.000376	<0.004	0.096	<5	7.65
Mann Park Sample Station	24-Jan-17	0.0057	0.0052	0.000333	<0.004	0.043	<5	7.73
Malabar Sample Station	24-Jan-17	0.0057	0.001	0.000228	0.005	0.033	<5	7.75
Marine Drive Sample Station	24-Jan-17	0.0058	0.0018	0.000283	0.005	0.029	<5	7.78
Russell Avenue Sample Station	24-Jan-17	0.0058	0.0006	0.000142	<0.004	0.068	<5	7.78
Stevens Sampling Station	26-Jan-17	0.0085	0.0035	0.000127	0.006	0.142	<5	7.63
Roper Sampling Station	26-Jan-17	0.0084	0.0024	0.000249	0.009	0.122	<5	7.79
Roper PRV - High Zone	26-Jan-17	0.0078	0.0018	0.000092	0.006	0.104	<5	7.79
Finlay Sampling Station	26-Jan-17	0.0071	0.0011	0.000094	0.007	0.103	<5	7.81
Kent St Activity Centre	26-Jan-17	0.0085	0.0049	0.000028	0.010	0.150	<5	7.87
Everall Sample Station	31-Jan-17	0.0058	0.0008	<0.00001	<0.004	0.095	<5	7.63
Mann Park Sample Station	31-Jan-17	0.0060	0.0041	0.000192	<0.004	0.054	<5	7.76
Malabar Sample Station	31-Jan-17	0.0057	0.0021	0.000162	<0.004	0.036	<5	7.78
Marine Drive Sample Station	31-Jan-17	0.0058	0.0031	0.000185	<0.004	0.024	<5	7.82
Russell Avenue Sample Station	31-Jan-17	0.0057	0.0015	0.000115	<0.004	0.064	<5	7.80
Stevens Sampling Station	31-Jan-17	0.0084	0.0042	0.002370	0.065	0.126	<5	7.73
Roper Sampling Station	31-Jan-17	0.0092	0.0024	0.000190	0.004	0.128	<5	7.85
Roper PRV - High Zone	31-Jan-17	0.0064	0.0120	0.000071	<0.004	0.066	<5	7.80
Finlay Sampling Station	31-Jan-17	0.0087	0.0010	0.000044	0.005	0.116	<5	7.87
Kent St Activity Centre	31-Jan-17	0.0086	0.0096	0.000070	0.007	0.126	<5	7.89

Oxford & Merklin Chlorination Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001	5	
Guideline Limit		0.0100	1	0.01	0.3	0.05		6.5 - 8.5
Everall Sample Station	07-Feb-17	0.0057	0.0009	0.000058	<0.004	0.090	<5	7.56
Mann Park Sample Station	07-Feb-17	0.0056	0.0062	0.000753	0.008	0.047	<5	7.71
Malabar Sample Station	07-Feb-17	0.0055	0.0036	0.000354	0.005	0.023	<5	7.75
Marine Drive Sample Station	07-Feb-17	0.0055	0.0020	0.000307	0.004	0.018	<5	7.77
Russell Avenue Sample Station	07-Feb-17	0.0056	0.0105	0.000492	0.013	0.106	<5	7.76
Stevens Sampling Station	08-Feb-17	0.0062	0.0017	0.000070	0.007	0.058	<5	7.77
Roper Sampling Station	08-Feb-17	0.0091	0.0023	0.000210	0.009	0.119	<5	7.87
Roper PRV - High Zone	08-Feb-17	0.0079	0.0017	<0.00001	0.005	0.105	<5	7.86
Finlay Sampling Station	08-Feb-17	0.0071	0.0009	0.000044	<0.004	0.075	<5	7.84
Kent St Activity Centre	08-Feb-17	0.0069	0.0059	<0.00001	0.008	0.070	<5	7.84
Everall Sample Station	15-Feb-17	0.0067	0.0012	0.000137	<0.004	0.086	<5	7.72
Mann Park Sample Station	15-Feb-17	0.0060	0.0118	0.000556	0.004	0.036	<5	7.76
Malabar Sample Station	15-Feb-17	0.0058	0.0030	0.000294	0.004	0.026	<5	7.76
Marine Drive Sample Station	15-Feb-17	0.0057	0.0023	0.000241	<0.004	0.017	<5	7.76
Russell Avenue Sample Station	15-Feb-17	0.0067	0.0016	0.000187	<0.004	0.052	<5	7.77
Stevens Sampling Station	15-Feb-17	0.0073	0.0025	0.000090	0.004	0.087	<5	7.80
Roper Sampling Station	15-Feb-17	0.0089	0.0026	0.000209	0.008	0.130	<5	7.87
Roper PRV - High Zone	15-Feb-17	0.0071	0.0022	0.000057	<0.004	0.076	<5	7.77
Finlay Sampling Station	15-Feb-17	0.0067	0.0008	0.000036	0.004	0.060	<5	7.78
Kent St Activity Centre	15-Feb-17	0.0080	0.0050	<0.00001	0.005	0.110	<5	7.81
Stevens Sampling Station	21-Feb-17	0.0088	0.0021	0.000108	0.004	0.111	<5	7.90
Malabar Sample Station	21-Feb-17	0.0066	0.0030	0.000224	0.005	0.021	<5	7.81
Marine Drive Sample Station	21-Feb-17	0.0067	0.0023	0.000192	<0.004	0.021	<5	7.77
Roper PRV - High Zone	21-Feb-17	0.0074	0.0015	0.000044	<0.004	0.058	<5	7.79
Finlay Sampling Station	22-Feb-17	0.0069	0.0009	0.000074	0.006	0.043	<5	7.84
Everall Sample Station	22-Feb-17	0.0066	0.0010	0.00012	0.005	0.114	12	7.84
Roper Sampling Station	22-Feb-17	0.0090	0.0024	0.000233	0.010	0.122	<5	7.92
Stayte Station	22-Feb-17	0.0074	0.0023	0.000151	0.009	0.042	<5	7.85
Oxford Station	22-Feb-17	0.0079	0.0014	0.000225	0.062	0.062	<5	7.88
Chestnut Street	22-Feb-17	0.0066	0.0013	0.000551	0.009	0.016	<5	7.86
Russell Avenue Sample Station	22-Feb-17	0.0090	0.0012	0.000222	0.007	0.116	<5	7.93
Everall Sample Station	28-Feb-17	0.0064	0.0011	0.000031	0.005	0.058	<5	7.72
Mann Park Sample Station	28-Feb-17	0.0065	0.0054	0.000256	<0.004	0.027	<5	7.75
Chestnut Street	28-Feb-17	0.0064	0.0019	0.000260	0.008	0.013	<5	7.80
Marine Drive Sample Station	28-Feb-17	0.0062	0.0043	0.000244	0.005	0.015	<5	7.77
Russell Avenue Sample Station	28-Feb-17	0.0089	0.0016	0.000194	0.006	0.118	<5	7.85
Stevens Sampling Station	28-Feb-17	0.0086	0.0024	0.000104	0.006	0.121	<5	7.84
Roper Sampling Station	28-Feb-17	0.0090	0.0033	0.000284	0.009	0.125	<5	7.87
Roper PRV - High Zone	28-Feb-17	0.0086	0.0012	<0.00001	0.004	0.106	<5	7.85
Finlay Sampling Station	28-Feb-17	0.0072	0.0010	0.000040	0.008	0.058	<5	7.81
Stayte Station	28-Feb-17	0.0080	0.0041	0.000383	0.017	0.053	<5	7.82
Oxford Station	28-Feb-17	0.0076	0.0013	0.00143	0.0048	0.078	<5	7.82
Balsam	28-Feb-17	0.0081	0.0601	0.000666	0.020	0.043	<5	7.82

Oxford & Merklin Chlorination Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001	5	
Guideline Limit		0.0100	1	0.01	0.3	0.05		6.5 - 8.5
Everall Sample Station	07-Mar-17	0.0063	0.0010	0.000066	<0.004	0.049	<5	7.76
Mann Park Sample Station	07-Mar-17	0.0064	0.0062	0.000253	<0.004	0.020	<5	7.78
Marine Drive Sample Station	07-Mar-17	0.0064	0.0041	0.000292	<0.004	0.014	<5	7.80
Russell Avenue Sample Station	07-Mar-17	0.0087	0.0013	0.000203	0.006	0.114	<5	7.88
Chestnut Street	07-Mar-17	0.0062	0.0012	0.000233	0.01	0.009	<5	7.79
Stevens Sampling Station	07-Mar-17	0.0091	0.0022	0.000127	0.006	0.124	<5	7.88
Roper Sampling Station	07-Mar-17	0.0088	0.0027	0.000317	0.009	0.118	<5	7.90
Roper PRV - High Zone	07-Mar-17	0.0086	0.0013	0.000045	0.006	0.107	<5	7.89
Finlay Sampling Station	07-Mar-17	0.0088	0.0009	0.000073	0.008	0.103	<5	7.90
Stayte Station	07-Mar-17	0.0082	0.0020	0.000382	0.011	0.061	<5	7.87
Oxford Station	07-Mar-17	0.0079	0.0008	0.000204	0.044	0.096	<5	7.86
Balsam	07-Mar-17	0.0076	0.0567	0.000950	0.041	0.074	<5	7.84
Everall Sample Station	14-Mar-17	0.0058	0.0011	0.000068	<0.004	0.030	<5	7.76
Malabar Sample Station	14-Mar-17	0.0055	0.0037	0.000320	0.004	0.010	<5	7.79
Marine Drive Sample Station	14-Mar-17	0.0056	0.0490	0.000348	0.004	0.008	<5	7.82
Russell Avenue Sample Station	14-Mar-17	0.0086	0.0011	0.000194	0.006	0.117	<5	7.93
Chestnut Street	14-Mar-17	0.0057	0.0014	0.000286	0.006	0.007	<5	7.82
Stevens Sampling Station	14-Mar-17	0.0085	0.0018	0.000119	0.006	0.124	<5	7.90
Roper Sampling Station	14-Mar-17	0.0084	0.0038	0.000435	0.007	0.117	<5	7.95
Roper PRV - High Zone	14-Mar-17	0.0085	0.0015	0.000038	<0.004	0.096	<5	7.95
Finlay Sampling Station	14-Mar-17	0.0073	0.0011	0.000081	0.005	0.081	<5	7.92
Stayte Station	14-Mar-17	0.0076	0.0019	0.000297	0.016	0.063	<5	7.95
Oxford Station	14-Mar-17	0.0070	0.0008	0.000255	0.025	0.099	<5	7.90
Balsam	14-Mar-17	0.0066	0.0318	0.000453	0.012	0.046	<5	7.89
Everall Sample Station	21-Mar-17	0.0059	0.0013	0.000076	<0.004	0.052	<5	7.73
Malabar Sample Station	21-Mar-17	0.0052	0.0051	0.000340	0.004	0.005	<5	7.77
Marine Drive Sample Station	21-Mar-17	0.0058	0.0044	0.000316	<0.004	0.008	<5	7.81
Russell Avenue Sample Station	21-Mar-17	0.0057	0.0021	0.000205	<0.004	0.015	<5	7.81
Chestnut Street	21-Mar-17	0.0052	0.0021	0.000202	0.004	0.006	<5	7.8
Stevens Sampling Station	21-Mar-17	0.0088	0.0021	0.000139	0.006	0.126	<5	7.93
Roper Sampling Station	21-Mar-17	0.0088	0.0028	0.000310	0.009	0.126	<5	7.94
Roper PRV - High Zone	21-Mar-17	0.0084	0.0014	0.000029	<0.004	0.089	<5	7.91
Finlay Sampling Station	21-Mar-17	0.0075	0.0009	0.000081	0.006	0.079	<5	7.89
Stayte Station	21-Mar-17	0.0076	0.0024	0.000327	0.012	0.052	<5	7.89
Oxford Station	21-Mar-17	0.0066	0.0008	0.000232	0.035	0.108	<5	7.87
Balsam	21-Mar-17	0.0081	0.0513	0.000620	0.024	0.059	<5	7.91
Everall Sample Station	29-Mar-17	0.0059	0.0013	0.000075	0.004	0.028	<5	7.79
Mann Park Sample Station	29-Mar-17	0.0057	0.0090	0.000219	<0.004	0.016	<5	7.76
Marine Drive Sample Station	29-Mar-17	0.0057	0.0051	0.000321	<0.004	0.007	<5	7.74
Russell Avenue Sample Station	29-Mar-17	0.0090	0.0012	0.000172	0.004	0.115	<5	7.86
Chestnut Street	29-Mar-17	0.0059	0.0019	0.000182	0.008	0.007	<5	7.76
Stevens Sampling Station	29-Mar-17	0.0088	0.0028	0.000142	0.007	0.122	<5	7.88
Roper Sampling Station	29-Mar-17	0.0088	0.0030	0.000306	0.008	0.114	<5	7.86
Roper PRV - High Zone	29-Mar-17	0.0086	0.0016	0.000029	0.005	0.100	<5	7.86
Finlay Sampling Station	29-Mar-17	0.0076	0.0010	0.000074	0.005	0.005	6	7.83
Stayte Station	29-Mar-17	0.0069	0.0024	0.000312	0.009	0.034	<5	7.79
Oxford Station	29-Mar-17	0.0069	0.0048	0.000263	0.022	0.096	<5	7.78
Balsam	29-Mar-17	0.0071	0.0765	0.000441	0.016	0.111	<5	7.82

Oxford & Merklin Chlorination Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001	5	
Guideline Limit		0.0100	1	0.01	0.3	0.05		6.5 - 8.5
Everall Sample Station	04-Apr-17	0.0062	0.0020	0.000088	<0.004	0.029	<5	7.66
Mann Park Sample Station	04-Apr-17	0.0062	0.0071	0.000342	<0.004	0.015	<5	7.68
Marine Drive Sample Station	04-Apr-17	0.0061	0.0045	0.000301	<0.004	0.008	<5	7.69
Russell Avenue Sample Station	04-Apr-17	0.0092	0.0011	0.000285	0.007	0.110	<5	7.81
Chestnut Street	04-Apr-17	0.0062	0.0014	0.000215	0.005	0.007	<5	7.71
Stevens Sampling Station	05-Apr-17	0.0091	0.0021	0.000153	0.006	0.122	<5	7.82
Roper PRV - High Zone	05-Apr-17	0.0087	0.0015	0.000049	0.005	0.108	<5	7.82
Finlay Sampling Station	05-Apr-17	0.0079	0.0015	0.0000955	0.006	0.093	<5	7.79
Stayte Station	05-Apr-17	0.0077	0.0025	0.000312	0.012	0.045	<5	7.70
Buena Vista Station	05-Apr-17	0.0078	0.0207	0.000377	0.014	0.084	<5	7.78
Balsam	05-Apr-17	0.0081	0.0257	0.000273	0.007	0.068	<5	7.74
Everall Sample Station	11-Apr-17	0.0059	0.0008	0.000067	<0.004	0.101	<5	7.69
Malabar Sample Station	11-Apr-17	0.0057	0.0041	0.000249	<0.004	0.049	<5	7.76
Marine Drive Sample Station	11-Apr-17	0.0061	0.0052	0.000362	<0.004	0.036	<5	7.80
Chestnut Street	11-Apr-17	0.0060	0.0013	0.000159	<0.004	0.028	<5	7.79
Stevens Sampling Station	11-Apr-17	0.0090	0.0024	0.000116	<0.004	0.143	<5	7.88
Roper Sampling Station	11-Apr-17	0.0089	0.0034	0.000343	<0.004	0.137	<5	7.88
Roper PRV - High Zone	11-Apr-17	0.0086	0.0012	0.000033	<0.004	0.125	<5	7.87
Finlay Sampling Station	11-Apr-17	0.0074	0.0010	0.000076	<0.004	0.0996	<5	7.87
Stayte Station	11-Apr-17	0.0074	0.0021	0.000285	0.011	0.078	<5	7.90
Buena Vista Station	11-Apr-17	0.0077	0.0091	0.000268	0.014	0.122	<5	7.83
Balsam	11-Apr-17	0.0082	0.0267	0.000523	0.006	0.089	<5	7.87
Everall Sample Station	24-Apr-17	0.0060	0.0017	0.000078	<0.004	0.030	<5	7.79
Malabar Sample Station	24-Apr-17	0.0060	0.0049	0.000305	<0.004	0.011	<5	7.83
Marine Drive Sample Station	24-Apr-17	0.0061	0.0043	0.000324	<0.004	0.009	<5	7.86
Russell Avenue Sample Station	24-Apr-17	0.0091	0.0011	0.000194	0.005	0.12	<5	7.96
Chestnut Street	24-Apr-17	0.0059	0.0021	0.000228	0.007	0.007	<5	7.86
Stevens Sampling Station	25-Apr-17	0.0089	0.0018	0.000148	0.005	0.13	<5	7.97
Roper Sampling Station	25-Apr-17	0.0089	0.0024	0.000324	0.006	0.13	<5	7.99
Roper PRV - High Zone	25-Apr-17	0.0088	0.0014	0.000075	<0.004	0.11	<5	7.96
Finlay Sampling Station	25-Apr-17	0.0076	0.0023	0.000110	0.005	0.077	<5	7.93
Stayte Station	25-Apr-17	0.0082	0.0042	0.000873	0.0099	0.069	<5	7.95
Oxford Station	25-Apr-17	0.0071	0.0059	0.000308	0.013	0.11	<5	7.79
Balsam	25-Apr-17	0.0071	0.0305	0.000363	0.008	0.060	<5	7.86
Everall Sample Station	28-Apr-17	0.0057	0.0016	0.000084	<0.004	0.021	<5	7.67
Malabar Sample Station	28-Apr-17	0.0057	0.0049	0.000425	<0.004	0.009	<5	7.74
Marine Drive Sample Station	28-Apr-17	0.0060	0.0048	0.000374	<0.004	0.012	<5	7.79
Russell Avenue Sample Station	28-Apr-17	0.0091	0.0011	0.000236	<0.004	0.12	<5	7.94
Chestnut Street	28-Apr-17	0.0059	0.0018	0.00028	<0.004	0.009	<5	7.81
Stevens Sampling Station	28-Apr-17	0.0092	0.0024	0.000161	<0.004	0.130	<5	7.93
Roper Sampling Station	28-Apr-17	0.0091	0.0040	0.000465	0.005	0.130	<5	7.94
Roper PRV - High Zone	28-Apr-17	0.0087	0.0013	0.000031	<0.004	0.11	<5	7.91
Finlay Sampling Station	28-Apr-17	0.0080	0.0016	0.000125	<0.004	0.091	<5	7.91
Stayte Station	28-Apr-17	0.0079	0.0028	0.000371	0.009	0.075	<5	7.90
Oxford Station	28-Apr-17	0.0082	0.0060	0.000343	0.012	0.14	<5	7.89
Balsam	28-Apr-17	0.0084	0.0286	0.000356	<0.004	0.081	<5	7.91

Oxford & Merklin Chlorination Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001	5	
Guideline Limit		0.0100	1	0.01	0.3	0.05		6.5 - 8.5
Everall Sample Station	02-May-17	0.0057	0.0014	0.000140	0.004	0.020	<5	7.77
Malabar Sample Station	02-May-17	0.0056	0.0044	0.000381	<0.004	0.0096	<5	7.82
Marine Drive Sample Station	02-May-17	0.0055	0.0044	0.000378	0.005	0.006	<5	7.81
Russell Avenue Sample Station	02-May-17	0.0089	0.0012	0.00029	0.005	0.11	<5	7.95
Chestnut Street	02-May-17	0.0056	0.0018	0.000192	0.006	0.006	<5	7.81
Stevens Sampling Station	02-May-17	0.0088	0.0016	0.000222	0.006	0.12	<5	7.96
Roper Sampling Station	02-May-17	0.0088	0.0032	0.000732	0.006	0.12	<5	7.96
Roper PRV - High Zone	02-May-17	0.0086	0.0014	0.000047	0.005	0.098	<5	7.83
Finlay Sampling Station	02-May-17	0.0078	0.0013	0.0000974	0.005	0.085	<5	7.92
Stayte Station	02-May-17	0.0081	0.0024	0.000329	0.010	0.070	<5	7.92
Oxford Station	02-May-17	0.0071	0.0063	0.000328	0.019	0.13	<5	7.90
Balsam	02-May-17	0.0072	0.0297	0.000383	0.005	0.060	<5	7.89
Everall Sample Station	04-May-17	0.0056	0.0041	0.000521	<0.004	0.041	<5	7.74
Mann Park Sample Station	04-May-17	0.0056	0.0070	0.000363	<0.004	0.011	<5	7.77
Marine Drive Sample Station	04-May-17	0.0057	0.0044	0.000329	<0.004	0.007	<5	7.80
Russell Avenue Sample Station	04-May-17	0.0088	0.0007	0.000159	<0.004	0.11	<5	7.91
Chestnut Street	04-May-17	0.0057	0.0017	0.000156	<0.004	0.006	<5	7.78
Stevens Sampling Station	04-May-17	0.0088	0.0019	0.000170	0.004	0.14	<5	7.93
Roper Sampling Station	04-May-17	0.0088	0.0019	0.000263	<0.004	0.12	<5	7.95
Roper PRV - High Zone	04-May-17	0.0087	0.0013	0.000040	<0.004	0.095	<5	7.89
Finlay Sampling Station	04-May-17	0.0079	0.0008	0.000060	<0.004	0.079	<5	7.87
Stayte Station	04-May-17	0.0080	0.0024	0.000357	<0.004	0.070	<5	7.89
Buena Vista Station	04-May-17	0.0071	0.0069	0.000326	0.008	0.11	<5	7.88
Balsam	04-May-17	0.0080	0.0215	0.000226	<0.004	0.078	<5	7.90
Everall Sample Station	09-May-17	0.0055	0.0021	0.000084	<0.004	0.032	<5	7.83
Mann Park Sample Station	09-May-17	0.0055	0.0101	0.000323	<0.004	0.012	<5	7.86
Marine Drive Sample Station	09-May-17	0.0055	0.0048	0.000394	<0.004	0.008	<5	7.88
Russell Avenue Sample Station	09-May-17	0.0086	0.0009	0.000178	0.006	0.12	<5	7.99
Chestnut Street	09-May-17	0.0055	0.0021	0.000198	0.0096	0.006	<5	7.80
Stevens Sampling Station	09-May-17	0.0087	0.0027	0.000177	0.005	0.13	<5	7.99
Roper Sampling Station	09-May-17	0.0086	0.0035	0.000438	0.007	0.13	<5	7.98
Roper PRV - High Zone	09-May-17	0.0085	0.0012	0.000078	0.006	0.11	<5	7.99
Finlay Sampling Station	09-May-17	0.0074	0.0036	0.000102	0.006	0.086	<5	7.94
Stayte Station	09-May-17	0.0078	0.0030	0.000437	0.008	0.072	<5	7.97
Buena Vista Station	09-May-17	0.0071	0.0059	0.000325	0.012	0.11	<5	7.95
Balsam	09-May-17	0.0078	0.0189	0.000281	0.009	0.096	<5	7.97
Everall Sample Station	11-May-17	0.0059	0.0018	0.000059	<0.004	0.015	<5	7.76
Malabar Sample Station	11-May-17	0.0056	0.0062	0.000421	<0.004	0.004	<5	7.83
Marine Drive Sample Station	11-May-17	0.0061	0.0051	0.000395	<0.004	0.008	<5	7.78
Russell Avenue Sample Station	11-May-17	0.0089	0.0010	0.000149	<0.004	0.12	<5	8.02
Chestnut Street	11-May-17	0.007	<0.005	<0.00010	0.006	0.007	<5	7.89
Stevens Sampling Station	11-May-17	0.0095	0.0029	0.000160	0.005	0.13	<5	8.00
Roper Sampling Station	11-May-17	0.0093	0.0033	0.000432	0.007	0.13	<5	8.02
Roper PRV - High Zone	11-May-17	0.0090	0.0015	0.000020	<0.004	0.11	<5	8.00
Finlay Sampling Station	11-May-17	0.0085	0.0028	0.000093	0.006	0.094	<5	7.91
Stayte Station	11-May-17	0.0082	0.0025	0.000322	0.008	0.075	<5	7.97
Buena Vista Station	11-May-17	0.0087	0.0066	0.000338	0.014	0.14	<5	7.96
Balsam	11-May-17	0.0083	0.0448	0.000411	0.009	0.092	<5	7.96
Everall Sample Station	16-May-17	0.0057	0.0015	0.000038	<0.004	0.024	<5	7.65
Malabar Sample Station	16-May-17	0.0056	0.0036	0.000341	<0.004	0.009	<5	7.74
Marine Drive Sample Station	16-May-17	0.0055	0.0040	0.000345	<0.004	0.007	<5	7.79
Russell Avenue Sample Station	16-May-17	0.0088	0.0011	0.000152	<0.004	0.12	<5	7.92
Chestnut Street	16-May-17	0.0056	0.0013	0.000155	<0.004	0.005	<5	7.81
Stevens Sampling Station	16-May-17	0.0087	0.0026	0.000129	0.004	0.13	<5	7.93
Roper Sampling Station	16-May-17	0.0089	0.0037	0.000432	<0.004	0.13	<5	7.96

Oxford & Merklin Chlorination Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001	5	
Guideline Limit		0.0100	1	0.01	0.3	0.05		6.5 - 8.5
Roper PRV - High Zone	16-May-17	0.0086	0.0013	<0.000010	<0.004	0.16	<5	7.96
Finlay Sampling Station	16-May-17	0.0086	0.0022	0.000051	<0.004	0.110	<5	8.02
Stayte Station	16-May-17	0.0078	0.0027	0.000343	0.005	0.080	<5	7.94
Buena Vista Station	16-May-17	0.0071	0.0061	0.000332	0.007	0.12	<5	7.90
Balsam	16-May-17	0.0072	0.0369	0.000301	<0.004	0.090	<5	7.90
Everall Sample Station	18-May-17	0.0055	0.0009	0.000068	<0.004	0.024	<5	7.73
Mann Park Sample Station	18-May-17	0.0053	0.0081	0.000264	<0.004	0.011	<5	7.77
Marine Drive Sample Station	18-May-17	0.0052	0.0037	0.000362	<0.004	0.003	<5	7.69
Russell Avenue Sample Station	18-May-17	0.0083	0.0012	0.000178	0.007	0.12	<5	7.92
Chestnut Street	18-May-17	0.0050	0.0016	0.000149	0.005	0.002	<5	7.80
Stevens Sampling Station	18-May-17	0.0084	0.0026	0.000158	0.007	0.13	<5	7.95
Roper Sampling Station	18-May-17	0.0086	0.0031	0.000413	0.008	0.13	<5	7.89
Roper PRV - High Zone	18-May-17	0.0082	0.0012	0.000029	0.006	0.12	<5	7.94
Finlay Sampling Station	18-May-17	0.0081	0.0012	0.000077	0.007	0.11	<5	7.95
Stayte Station	18-May-17	0.0075	0.0028	0.000313	0.008	0.082	<5	7.94
Buena Vista Station	18-May-17	0.0068	0.0048	0.000277	0.008	0.10	<5	7.93
Balsam	18-May-17	0.0071	0.0310	0.000296	0.0096	0.097	<5	7.94
Everall Sample Station	23-May-17	0.0054	0.0013	0.000078	<0.004	0.025	<5	7.75
Mann Park Sample Station	23-May-17	0.0053	0.0089	0.000280	<0.004	0.012	<5	7.81
Marine Drive Sample Station	23-May-17	0.0052	0.0051	0.000429	0.004	0.006	<5	7.83
Russell Avenue Sample Station	23-May-17	0.0082	0.0012	0.000146	0.005	0.12	<5	7.93
Chestnut Street	23-May-17	0.0052	0.0016	0.000185	0.006	0.003	<5	7.83
Stevens Sampling Station	23-May-17	0.0083	0.0026	0.000158	0.006	0.12	<5	7.96
Roper Sampling Station	23-May-17	0.0083	0.0041	0.000498	0.008	0.12	<5	8.00
Roper PRV - High Zone	23-May-17	0.0082	0.0008	0.000062	<0.004	0.11	<5	7.99
Finlay Sampling Station	23-May-17	0.0079	0.0017	0.000081	0.005	0.11	<5	7.98
Stayte Station	23-May-17	0.0076	0.0031	0.000432	0.007	0.087	<5	7.95
Buena Vista Station	23-May-17	0.0074	0.0070	0.000312	0.0096	0.14	<5	7.96
Balsam	23-May-17	0.0079	0.0157	0.000170	0.008	0.11	<5	7.97
Everall Sample Station	25-May-17	0.0058	0.0014	0.0000969	0.013	0.026	<5	7.65
Malabar Sample Station	25-May-17	0.0057	0.0046	0.000453	<0.004	0.008	<5	7.76
Marine Drive Sample Station	25-May-17	0.0058	0.0057	0.000487	0.004	0.004	<5	7.81
Russell Avenue Sample Station	25-May-17	0.0091	0.0017	0.000200	0.004	0.12	<5	7.92
Chestnut Street	25-May-17	0.0058	0.0021	0.000203	0.006	0.004	<5	7.81
Stevens Sampling Station	25-May-17	0.0090	0.0027	0.000198	0.006	0.130	<5	7.94
Roper Sampling Station	25-May-17	0.0089	0.0038	0.000510	0.008	0.120	<5	7.94
Roper PRV - High Zone	25-May-17	0.0088	0.0015	0.000041	0.005	0.120	<5	7.94
Finlay Sampling Station	25-May-17	0.0087	0.0013	0.000104	0.006	0.11	<5	7.94
Stayte Station	25-May-17	0.0081	0.0028	0.000379	0.011	0.078	<5	7.93
Buena Vista Station	25-May-17	0.0086	0.0116	0.000463	0.014	0.14	<5	7.92
Balsam	25-May-17	0.0087	0.0232	0.000424	0.014	0.10	<5	7.95
Everall Sample Station	30-May-17	0.0059	0.0011	0.000066	<0.004	0.027	<5	7.59
Malabar Sample Station	30-May-17	0.0059	0.004	0.000402	<0.004	0.009	<5	7.76
Marine Drive Sample Station	30-May-17	0.0058	0.0052	0.000480	<0.004	0.005	<5	7.77
Russell Avenue Sample Station	30-May-17	0.0091	0.0013	0.000157	0.005	0.12	<5	7.88
Chestnut Street	30-May-17	0.0059	0.0015	0.000162	0.007	0.004	<5	7.79
Stevens Sampling Station	30-May-17	0.0091	0.0026	0.000168	<0.004	0.12	<5	7.89
Roper Sampling Station	30-May-17	0.0091	0.0025	0.000395	0.011	0.12	<5	7.91
Roper PRV - High Zone	30-May-17	0.0090	0.0014	0.000031	0.005	0.11	<5	7.91
Finlay Sampling Station	30-May-17	0.0085	0.0014	0.000083	<0.004	0.10	<5	7.91
Stayte Station	30-May-17	0.0087	0.0033	0.000454	0.006	0.088	<5	7.92
Buena Vista Station	30-May-17	0.0088	0.0067	0.000358	0.0097	0.12	<5	7.96
Balsam	30-May-17	0.0088	0.0501	0.000553	0.017	0.10	<5	7.89
Everall Sample Station	01-Jun-17	0.0062	0.0014	0.000082	<0.004	0.026	<5	7.90
Mann Park Sample Station	01-Jun-17	0.0062	0.0108	0.000554	<0.004	0.015	<5	7.97

Oxford & Merklin Chlorination Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001	5	
Guideline Limit		0.0100	1	0.01	0.3	0.05		6.5 - 8.5
Marine Drive Sample Station	01-Jun-17	0.0061	0.0060	0.000570	<0.004	0.004	<5	8.00
Russell Avenue Sample Station	01-Jun-17	0.0094	0.0018	0.000201	0.006	0.12	<5	8.08
Chestnut Street	01-Jun-17	0.0063	0.0024	0.000225	0.004	0.006	<5	7.98
Stevens Sampling Station	01-Jun-17	0.0096	0.0025	0.000222	0.005	0.12	<5	8.09
Roper Sampling Station	01-Jun-17	0.0096	0.0040	0.000590	0.006	0.12	<5	8.09
Roper PRV - High Zone	01-Jun-17	0.0098	0.0020	0.000044	0.005	0.12	<5	8.12
Finlay Sampling Station	01-Jun-17	0.0094	0.0016	0.000120	0.004	0.11	<5	8.07
Stayte Station	01-Jun-17	0.0092	0.0033	0.000511	0.006	0.087	<5	8.09
Buena Vista Station	01-Jun-17	0.0089	0.0071	0.000401	0.014	0.17	<5	8.07
Balsam	01-Jun-17	0.0090	0.0386	0.000552	0.009	0.10	<5	8.09
Everall Sample Station	13-Jun-17	0.0056	0.0012	0.00006	<0.004	0.033	<5	7.74
Malabar Sample Station	13-Jun-17	0.0059	0.0028	0.00035	<0.004	0.011	<5	7.80
Russell Avenue Sample Station	13-Jun-17	0.0085	0.0012	0.00016	<0.004	0.14	<5	7.94
Chestnut Street	13-Jun-17	0.0054	0.0014	0.00017	0.008	0.005	<5	7.80
Stevens Sampling Station	13-Jun-17	0.0084	0.0019	0.00012	0.006	0.13	<5	7.80
Roper Sampling Station	13-Jun-17	0.0084	0.0026	0.00049	0.005	0.13	<5	7.90
Roper PRV - High Zone	13-Jun-17	0.0084	0.0009	0.00004	0.004	0.13	<5	7.93
Finlay Sampling Station	13-Jun-17	0.0081	0.0018	0.00010	0.004	0.11	<5	7.92
Stayte Station	13-Jun-17	0.0080	0.0020	0.00032	0.006	0.099	<5	7.82
Buena Vista Station	13-Jun-17	0.0074	0.0007	0.00025	0.013	0.18	<5	7.89
Balsam	13-Jun-17	0.0084	0.0179	0.00022	0.006	0.11	<5	7.92
Everall Sample Station	21-Jun-17	0.0056	0.0013	0.00010	<0.004	0.035	<5	7.62
Mann Park Sample Station	21-Jun-17	0.0058	0.0085	0.00035	0.005	0.018	<5	7.82
Marine Drive Sample Station	21-Jun-17	0.0055	0.0062	0.00059	0.004	0.005	<5	7.85
Russell Avenue Sample Station	21-Jun-17	0.0082	0.0015	0.00021	0.005	0.13	<5	7.96
Stevens Sampling Station	21-Jun-17	0.0082	0.0028	0.00018	0.005	0.13	<5	7.98
Roper PRV - High Zone	21-Jun-17	0.0081	0.0015	0.00005	0.004	0.13	<5	7.97
Finlay Sampling Station	21-Jun-17	0.0080	0.0018	0.00012	0.007	0.12	<5	7.98
Stayte Station	21-Jun-17	0.0077	0.0039	0.00068	0.008	0.10	<5	7.98
Buena Vista Station	21-Jun-17	0.0077	0.0141	0.00056	0.022	0.20	<5	7.97
Balsam	21-Jun-17	0.0083	0.0185	0.00029	0.008	0.12	<5	8.00
Everall Sample Station	27-Jun-17	0.0059	0.0015	0.00015	0.005	0.062	<5	7.65
Malabar Sample Station	27-Jun-17	0.0058	0.0034	0.00047	<0.004	0.017	<5	7.82
Chestnut Street	27-Jun-17	0.0059	0.0021	0.00025	0.009	0.008	<5	7.84
Russell Avenue Sample Station	27-Jun-17	0.0088	0.0019	0.00024	0.005	0.12	<5	7.90
Roper PRV - High Zone	27-Jun-17	0.0083	0.0010	0.00004	<0.004	0.10	<5	7.94
Roper Sampling Station	27-Jun-17	0.0088	0.0033	0.00051	0.005	0.12	<5	7.95
Finlay Sampling Station	27-Jun-17	0.0076	0.0063	0.00013	0.006	0.087	<5	7.92
Stayte Station	27-Jun-17	0.0075	0.0032	0.00060	0.011	0.099	<5	7.90
Balsam	27-Jun-17	0.0084	0.0196	0.00039	0.006	0.098	<5	7.94
Buena Vista Station	27-Jun-17	0.0081	0.0068	0.00042	0.013	0.15	<5	7.90
Everall Sample Station	06-Jul-17	0.0059	0.0024	0.00062	<0.004	0.069	<5	7.59
Mann Park Sample Station	06-Jul-17	0.0059	0.0072	0.00035	<0.004	0.032	<5	7.74
Marine Drive Sample Station	06-Jul-17	0.0059	0.0049	0.00059	<0.004	0.11	<5	7.79
Russell Avenue Sample Station	06-Jul-17	0.0089	0.0018	0.00023	<0.004	0.13	<5	7.89
Roper PRV - High Zone	06-Jul-17	0.0086	0.0012	0.00004	<0.004	0.13	<5	7.90
Stevens Sampling Station	06-Jul-17	0.0089	0.0016	0.00017	<0.004	0.14	<5	7.93
Finlay Sampling Station	06-Jul-17	0.0082	0.0014	0.00011	<0.004	0.11	<5	7.93
Stayte Station	06-Jul-17	0.0077	0.0023	0.00030	<0.004	0.093	<5	7.89
Balsam	06-Jul-17	0.0088	0.0207	0.00023	0.004	0.13	<5	7.92
Buena Vista Station	06-Jul-17	0.0077	0.0131	0.00077	<0.004	0.10	<5	7.90

Oxford & Merklin Chlorination Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001	5	
Guideline Limit		0.0100	1	0.01	0.3	0.05		6.5 - 8.5
Everall Sample Station	11-Jul-17	0.0058	0.0015	0.00007	<0.004	0.068	<5	7.66
Malabar Sample Station	11-Jul-17	0.0057	0.0046	0.00055	<0.004	0.023	<5	7.81
Chestnut Street	11-Jul-17	0.0057	0.0018	0.00016	<0.004	0.011	<5	7.85
Russell Avenue Sample Station	12-Jul-17	0.0085	0.0021	0.00016	<0.004	0.13	<5	7.92
Roper PRV - High Zone	12-Jul-17	0.0085	0.0010	0.00001	<0.004	0.13	<5	7.96
Roper Sampling Station	12-Jul-17	0.0084	0.0067	0.00088	<0.004	0.13	<5	7.96
Finlay Sampling Station	12-Jul-17	0.0081	0.0014	0.00009	<0.004	0.12	<5	7.92
Stayte Station	12-Jul-17	0.0075	0.0032	0.00056	<0.004	0.093	<5	7.93
Balsam	12-Jul-17	0.0084	0.0196	0.00025	<0.004	0.11	<5	7.96
Buena Vista Station	12-Jul-17	0.0080	0.0065	0.00034	<0.004	0.11	<5	7.90
Everall Sample Station	18-Jul-17	0.0058	0.0018	0.00009	<0.004	0.069	<5	7.63
Mann Park Sample Station	18-Jul-17	0.0057	0.0089	0.00025	<0.004	0.039	<5	7.78
Marine Drive Sample Station	18-Jul-17	0.0059	0.0049	0.00048	0.006	0.016	<5	7.82
Russell Avenue Sample Station	18-Jul-17	0.0087	0.0018	0.00016	<0.004	0.12	<5	7.92
Roper PRV - High Zone	18-Jul-17	0.0083	0.0015	0.00002	0.004	0.12	<5	7.79
Stevens Sampling Station	18-Jul-17	0.0087	0.0028	0.00020	0.004	0.13	<5	7.91
Finlay Sampling Station	19-Jul-17	0.0082	0.0013	0.00008	0.006	0.11	<5	7.92
Stayte Station	19-Jul-17	0.0076	0.0038	0.00118	0.007	0.094	<5	7.92
Balsam	19-Jul-17	0.0084	0.0258	0.00030	0.008	0.12	<5	7.83
Buena Vista Station	19-Jul-17	0.0083	0.0084	0.00046	0.010	0.12	<5	7.92
Everall Sample Station	25-Jul-17	0.0062	0.0013	0.00008	<0.004	0.069	<5	7.62
Malabar Sample Station	25-Jul-17	0.0061	0.0042	0.00049	<0.004	0.028	<5	7.79
Chestnut Street	25-Jul-17	0.0061	0.0017	0.00018	0.005	0.017	<5	7.82
Russell Avenue Sample Station	25-Jul-17	0.0090	0.0020	0.00019	<0.004	0.13	<5	7.96
Roper PRV - High Zone	25-Jul-17	0.0088	0.0014	0.00003	<0.004	0.12	<5	7.96
Roper Sampling Station	25-Jul-17	0.0091	0.0035	0.00065	<0.004	0.13	<5	7.96
Finlay Sampling Station	25-Jul-17	0.0084	0.0013	0.00009	<0.004	0.11	<5	7.93
Stayte Station	25-Jul-17	0.0078	0.0043	0.00160	<0.004	0.093	<5	7.91
Balsam	25-Jul-17	0.0088	0.0179	0.00032	<0.004	0.11	<5	7.95
Buena Vista Station	25-Jul-17	0.0086	0.0071	0.00040	0.004	0.12	<5	7.93
Everall Sample Station	02-Aug-17	0.0059	0.0014	0.00009	<0.004	0.075	<5	7.86
Mann Park Sample Station	01-Aug-17	0.0058	0.0079	0.00027	<0.004	0.047	<5	7.67
Marine Drive Sample Station	01-Aug-17	0.0059	0.0043	0.00045	<0.004	0.019	<5	7.84
Russell Avenue Sample Station	02-Aug-17	0.0086	0.0019	0.00015	<0.004	0.12	<5	7.94
Roper PRV - High Zone	02-Aug-17	0.0083	0.0014	0.00005	<0.004	0.11	<5	7.95
Stevens Sampling Station	02-Aug-17	0.0084	0.0033	0.00022	<0.004	0.12	<5	7.95
Finlay Sampling Station	02-Aug-17	0.0080	0.0011	0.00010	<0.004	0.11	<5	7.93
Stayte Station	02-Aug-17	0.0069	0.0034	0.00096	<0.004	0.087	<5	7.89
Balsam	02-Aug-17	0.0083	0.0174	0.00024	<0.004	0.10	<5	7.94
Buena Vista Station	01-Aug-17	0.0080	0.0085	0.00050	0.004	0.11	<5	7.88
Roper PRV - High Zone	08-Aug-17	0.0086	0.00097	<0.00001	0.004	0.12	<5	7.68
Buena Vista Station	08-Aug-17	0.0080	0.0016	0.00023	0.011	0.13	<5	7.86
Malabar Sample Station	08-Aug-17	0.0060	0.0035	0.00032	<0.004	0.041	<5	7.83
Chestnut Street	08-Aug-17	0.0060	0.0012	0.00012	0.007	0.020	<5	7.84
Stayte Station	09-Aug-17	0.0075	0.0031	0.00053	0.005	0.092	<5	7.91
Balsam	09-Aug-17	0.0087	0.0219	0.00029	0.006	0.11	<5	7.95
Finlay Sampling Station	09-Aug-17	0.0090	0.0009	0.00004	0.005	0.12	<5	7.99
Everall Sample Station	09-Aug-17	0.0062	0.0013	0.00003	<0.004	0.077	<5	7.89
Russell Avenue Sample Station	09-Aug-17	0.0090	0.0016	0.00008	0.004	0.13	<5	7.97
Roper Sampling Station	09-Aug-17	0.0087	0.0058	0.00096	0.006	0.12	<5	7.98

Oxford & Merklin Chlorination Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001	5	
Guideline Limit		0.0100	1	0.01	0.3	0.05		6.5 - 8.5
Buena Vista Station	15-Aug-17	0.0078	0.0015	0.00022	0.007	0.11	6	7.87
Mann Park Sample Station	15-Aug-17	0.0056	0.0077	0.00025	0.005	0.043	5	7.80
Stayte Station	15-Aug-17	0.0068	0.0032	0.00056	0.008	0.088	6	7.64
Balsam	15-Aug-17	0.0079	0.0225	0.00029	0.004	0.10	6	7.84
Finlay Sampling Station	15-Aug-17	0.0075	0.00097	0.00008	0.005	0.10	7	7.87
Stevens Sampling Station	15-Aug-17	0.0084	0.0027	0.00016	0.004	0.12	8	7.91
Everall Sample Station	15-Aug-17	0.0056	0.0019	0.000098	<0.004	0.069	8	7.57
Russell Avenue Sample Station	15-Aug-17	0.0068	0.0016	0.00012	<0.004	0.079	10	7.79
Marine Drive Sample Station	15-Aug-17	0.0057	0.0039	0.00041	0.004	0.022	14	7.80
Roper PRV - High Zone	15-Aug-17	0.0078	0.0013	0.00003	<0.004	0.11	22	7.90
Buena Vista Station	22-Aug-17	0.0079	0.0013	0.00022	0.004	0.12	<5	7.64
Malabar Sample Station	22-Aug-17	0.0057	0.0033	0.00042	<0.004	0.048	<5	7.70
Stayte Station	22-Aug-17	0.0069	0.0044	0.00081	<0.004	0.099	<5	7.79
Balsam	22-Aug-17	0.0081	0.0294	0.00037	<0.004	0.12	<5	7.85
Finlay Sampling Station	22-Aug-17	0.0078	0.0009	0.00011	<0.004	0.12	<5	7.86
Everall Sample Station	22-Aug-17	0.0057	0.0016	0.00009	<0.004	0.13	<5	7.78
Russell Avenue Sample Station	22-Aug-17	0.0083	0.0012	0.00013	<0.004	0.13	<5	7.88
Roper Sampling Station	22-Aug-17	0.0082	0.0041	0.00096	<0.004	0.13	<5	7.90
Chestnut Street	22-Aug-17	0.0057	0.0011	0.00012	<0.004	0.026	<5	7.79
Roper PRV - High Zone	22-Aug-17	0.0077	0.0011	0.00003	<0.004	0.12	<5	7.87
Everall Sample Station	29-Aug-17	0.0065	0.0013	0.00009	0.009	0.13	<5	7.49
Mann Park Sample Station	29-Aug-17	0.0066	0.0061	0.00022	<0.004	0.094	<5	7.74
Marine Drive Sample Station	29-Aug-17	0.0066	0.0033	0.00039	0.006	0.047	<5	7.78
Russell Avenue Sample Station	29-Aug-17	0.0085	0.0009	0.00009	0.006	0.13	<5	7.88
Roper PRV - High Zone	29-Aug-17	0.0083	0.0019	0.00006	<0.004	0.13	<5	7.89
Stevens Sampling Station	29-Aug-17	0.0085	0.0027	0.00018	0.010	0.16	<5	7.93
Finlay Sampling Station	30-Aug-17	0.0083	0.0008	0.00009	0.004	0.12	<5	7.81
Stayte Station	30-Aug-17	0.0075	0.0027	0.00044	0.007	0.10	<5	7.86
Balsam	30-Aug-17	0.0075	0.0331	0.00041	0.009	0.12	<5	7.88
Buena Vista Station	30-Aug-17	0.0075	0.0014	0.00021	0.008	0.12	<5	7.90
Everall Sample Station	05-Sep-17	0.0068	0.0018	0.00009	<0.004	0.12	<5	7.63
Malabar Sample Station	05-Sep-17	0.0068	0.0034	0.00039	<0.004	0.058	<5	7.82
Chestnut Street	05-Sep-17	0.0068	0.0013	0.00013	0.007	0.057	<5	7.85
Russell Avenue Sample Station	05-Sep-17	0.0078	0.0050	0.00044	<0.004	0.12	<5	7.89
Roper PRV - High Zone	05-Sep-17	0.0087	0.0020	0.00005	0.005	0.13	<5	7.93
Roper Sampling Station	06-Sep-17	0.0089	0.0045	0.00072	0.004	0.12	<5	7.95
Finlay Sampling Station	06-Sep-17	0.0088	0.0010	0.00009	<0.004	0.11	<5	7.93
Stayte Station	06-Sep-17	0.0079	0.0033	0.00054	0.006	0.11	<5	7.90
Balsam	06-Sep-17	0.0082	0.0300	0.00042	<0.004	0.086	<5	7.91
Buena Vista Station	06-Sep-17	0.0081	0.0024	0.00034	0.005	0.15	<5	7.90
Everall Sample Station	12-Sep-17	0.0070	0.0014	0.00008	<0.004	0.11	<5	7.60
Mann Park Sample Station	12-Sep-17	0.0069	0.0061	0.00025	<0.004	0.092	<5	7.78
Marine Drive Sample Station	12-Sep-17	0.0069	0.0039	0.00042	0.005	0.049	<5	7.81
Russell Avenue Sample Station	12-Sep-17	0.0070	0.0011	0.00010	<0.004	0.095	<5	7.81
Roper PRV - High Zone	12-Sep-17	0.0088	0.0012	0.00005	0.017	0.13	<5	7.88
Stevens Sampling Station	12-Sep-17	0.0093	0.0032	0.00020	0.005	0.13	<5	7.91
Finlay Sampling Station	12-Sep-17	0.0091	0.0012	0.00011	<0.004	0.13	<5	7.90
Stayte Station	12-Sep-17	0.0073	0.0051	0.00088	0.006	0.099	<5	7.81
Balsam	12-Sep-17	0.0084	0.0350	0.00051	0.005	0.12	<5	7.87
Oxford & Buena Vista Station	12-Sep-17	0.0078	0.0012	0.00020	0.007	0.14	<5	7.85
Roper PRV - High Zone	19-Sep-17	0.0085	0.0009	0.00004	<0.004	0.13	<5	8.16
Roper Sampling Station	19-Sep-17	0.0091	0.0029	0.00045	0.005	0.13	<5	8.21
Finlay Sampling Station	19-Sep-17	0.0083	0.0012	0.000099	0.005	0.13	<5	8.19
Stayte Station	19-Sep-17	0.0073	0.0032	0.00046	0.004	0.12	<5	8.15
Balsam	19-Sep-17	0.0082	0.0383	0.00035	<0.004	0.12	<5	8.20

Oxford & Merklin Chlorination Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001	5	
Guideline Limit		0.0100	1	0.01	0.3	0.05		6.5 - 8.5
Everall Sample Station	20-Sep-17	0.0070	0.0013	0.00008	<0.004	0.12	<5	8.16
Malabar Sample Station	20-Sep-17	0.0070	0.0031	0.00035	<0.004	0.093	<5	8.17
Chestnut Street	20-Sep-17	0.0070	0.0013	0.00014	0.011	0.055	<5	8.16
Russell Avenue Sample Station	20-Sep-17	0.0070	0.0012	0.00011	<0.004	0.10	<5	8.17
Oxford & Buena Vista Station	20-Sep-17	0.0071	0.0011	0.00012	0.005	0.13	<5	8.18
Everall Sample Station	26-Sep-17	0.0067	0.0007	0.00005	<0.004	0.11	<5	8.10
Mann Park Sample Station	26-Sep-17	0.0067	0.0076	0.00024	<0.004	0.096	<5	8.13
Marine Drive Sample Station	26-Sep-17	0.0068	0.0034	0.00029	<0.004	0.062	<5	8.13
Russell Avenue Sample Station	26-Sep-17	0.0067	0.0009	0.00008	<0.004	0.10	<5	8.13
Roper PRV - High Zone	26-Sep-17	0.0077	0.0009	<0.00001	0.005	0.12	<5	8.16
Stevens Sampling Station	26-Sep-17	0.0088	0.0022	0.000098	<0.004	0.12	<5	8.19
Finlay Sampling Station	26-Sep-17	0.0071	0.0011	0.00005	<0.004	0.10	<5	8.15
Stayte Station	26-Sep-17	0.0073	0.0038	0.00050	0.004	0.11	<5	8.15
Balsam	26-Sep-17	0.0077	0.0287	0.00030	<0.004	0.073	<5	8.17
Oxford & Buena Vista Station	26-Sep-17	0.0067	0.0011	0.00011	0.006	0.12	<5	8.14
Stevens Sampling Station	04-Oct-17	0.0084	0.0026	0.00014	0.007	0.12	<5	8.14
Finlay Sampling Station	04-Oct-17	0.0066	0.0011	0.00009	0.004	0.090	<5	8.13
Stayte Station	04-Oct-17	0.0067	0.0036	0.00054	0.007	0.093	<5	8.14
Balsam	04-Oct-17	0.0070	0.0320	0.00050	0.007	0.087	<5	8.11
Oxford & Buena Vista Station	04-Oct-17	0.0063	0.0009	0.00012	0.006	0.089	<5	8.11
Everall Sample Station	03-Oct-17	0.0061	0.001	0.0001	0.02	0.056	<5	7.94
Mann Park Sample Station	03-Oct-17	0.0058	0.006	0.0003	<0.01	0.046	<5	7.99
Marine Drive Sample Station	03-Oct-17	0.0059	0.005	0.0004	<0.01	0.052	<5	8.06
Russell Avenue Sample Station	03-Oct-17	0.0060	0.001	0.0001	<0.01	0.049	<5	8.04
Roper PRV - High Zone	03-Oct-17	0.0081	0.001	<0.0001	0.01	0.101	<5	8.13
Everall Sample Station	10-Oct-17	0.0057	0.0016	0.00009	0.005	0.051	<5	8.04
Malabar Sample Station	10-Oct-17	0.0056	0.0031	0.00038	0.006	0.037	<5	8.07
Chestnut Street	10-Oct-17	0.0056	0.0013	0.00018	0.0096	0.028	<5	8.08
Russell Avenue Sample Station	10-Oct-17	0.0057	0.0009	0.000095	<0.004	0.047	<5	8.09
Roper Sampling Station	10-Oct-17	0.0068	0.00099	0.00004	<0.004	0.075	<5	8.13
Roper Sampling Station	11-Oct-17	0.0088	0.0021	0.00032	0.005	0.12	<5	8.12
Finlay Sampling Station	11-Oct-17	0.0062	0.0018	0.00006	0.004	0.071	<5	8.10
Stayte Station	11-Oct-17	0.0064	0.0028	0.00037	0.007	0.077	<5	8.14
Balsam	11-Oct-17	0.0064	0.0381	0.00032	0.010	0.072	<5	8.11
Oxford & Buena Vista Station	11-Oct-17	0.0066	0.0011	0.00013	0.008	0.092	<5	8.12
Stevens Sampling Station	18-Oct-17	0.0080	0.0022	0.000096	0.005	0.11	<5	8.09
Finlay Sampling Station	18-Oct-17	0.0064	0.0016	0.00008	<0.04	0.08	<5	8.12
Stayte Station	18-Oct-17	0.0062	0.0031	0.00038	0.007	0.068	<5	8.12
Balsam	18-Oct-17	0.0059	0.0368	0.00040	0.006	0.062	<5	8.12
Oxford & Buena Vista Station	18-Oct-17	0.0056	0.0013	0.00013	0.016	0.074	<5	8.01
Everall Sample Station	17-Oct-17	0.0056	0.0008	0.00007	<0.004	0.043	<5	8.04
Mann Park Sample Station	17-Oct-17	0.0057	0.0064	0.00028	<0.004	0.041	<5	8.13
Marine Drive Sample Station	17-Oct-17	0.0056	0.0010	0.00011	0.006	0.037	<5	8.16
Russell Avenue Sample Station	17-Oct-17	0.0057	0.0043	0.00050	<0.004	0.042	<5	8.13
Roper PRV - High Zone	17-Oct-17	0.0067	0.00097	0.00003	<0.004	0.068	<5	8.16
Everall Sample Station	24-Oct-17	0.0057	0.0011	0.00006	<0.004	0.042	<5	8.18
Malabar Sample Station	24-Oct-17	0.0057	0.0033	0.00033	<0.004	0.033	<5	8.12
Chestnut Street	24-Oct-17	0.0056	0.0017	0.00014	0.010	0.028	<5	8.08
Russell Avenue Sample Station	24-Oct-17	0.0056	0.0012	0.000099	<0.004	0.033	<5	8.09
Roper PRV - High Zone	24-Oct-17	0.0070	0.0012	0.00001	<0.004	0.079	<5	8.13
Roper Sampling Station	24-Oct-17	0.0085	0.0023	0.00032	0.006	0.12	<5	8.19
Finlay Sampling Station	24-Oct-17	0.0066	0.0015	0.00006	0.005	0.069	<5	8.12
Stayte Station	24-Oct-17	0.0064	0.0027	0.00031	0.006	0.061	<5	8.12
Balsam	24-Oct-17	0.0059	0.0317	0.00047	0.007	0.053	<5	8.11
Oxford & Buena Vista Station	24-Oct-17	0.0057	0.0012	0.00011	0.006	0.071	<5	8.08

Oxford & Merklin Chlorination Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001	5	
Guideline Limit		0.0100	1	0.01	0.3	0.05		6.5 - 8.5
Everall Sample Station	31-Oct-17	0.0058	0.0011	0.00006	<0.004	0.040	6	8.10
Mann Park Sample Station	31-Oct-17	0.0058	0.0067	0.00021	<0.004	0.038	<5	8.10
Marine Drive Sample Station	31-Oct-17	0.0058	0.0039	0.00029	0.005	0.030	<5	8.12
Russell Avenue Sample Station	31-Oct-17	0.0058	0.0010	0.00011	<0.004	0.036	<5	8.10
Roper PRV - High Zone	31-Oct-17	0.0071	0.0007	0.00003	<0.004	0.078	<5	8.17
Stevens Sampling Station	31-Oct-17	0.0063	0.0027	0.00013	<0.004	0.069	<5	8.11
Finlay Sampling Station	31-Oct-17	0.0064	0.0010	0.00006	<0.004	0.058	<5	8.12
Stayte Station	31-Oct-17	0.0062	0.0035	0.00041	0.005	0.064	<5	8.14
Balsam	31-Oct-17	0.0060	0.0257	0.00031	<0.004	0.048	5	8.14
Oxford & Buena Vista Station	31-Oct-17	0.0061	0.0009	0.00009	0.004	0.069	6	8.15
Everall Sample Station	07-Nov-17	0.0053	0.0011	0.000098	<0.004	0.021	<5	7.94
Malabar Sample Station	07-Nov-17	0.0055	0.0030	0.00040	<0.004	0.021	<5	7.93
Chestnut Street	07-Nov-17	0.0054	0.0015	0.00016	0.011	0.020	<5	8.03
Russell Avenue Sample Station	07-Nov-17	0.0085	0.00097	0.00011	0.006	0.12	<5	8.11
Roper PRV - High Zone	07-Nov-17	0.0078	0.0008	0.00003	0.006	0.10	<5	8.14
Roper Sampling Station	07-Nov-17	0.0085	0.0027	0.00035	0.006	0.12	<5	8.16
Finlay Sampling Station	07-Nov-17	0.0078	0.0011	0.00008	0.015	0.10	<5	8.17
Stayte Station	07-Nov-17	0.0073	0.0031	0.00035	0.011	0.081	<5	8.17
Balsam	07-Nov-17	0.0065	0.0387	0.00036	0.011	0.063	<5	8.12
Oxford & Buena Vista Station	07-Nov-17	0.0062	0.0011	0.00010	0.007	0.069	<5	8.13
Everall Sample Station	14-Nov-17	0.0052	0.0009	0.00006	<0.004	0.022	<5	8.14
Mann Park Sample Station	14-Nov-17	0.0054	0.0065	0.00020	<0.004	0.022	<5	8.17
Marine Drive Sample Station	14-Nov-17	0.0052	0.0039	0.00027	0.010	0.024	<5	8.20
Russell Avenue Sample Station	14-Nov-17	0.0078	0.0009	0.00010	<0.004	0.12	<5	8.26
Roper PRV - High Zone	14-Nov-17	0.0080	0.0009	0.00010	<0.004	0.11	<5	8.27
Stevens Sampling Station	14-Nov-17	0.0082	0.0025	0.00012	<0.004	0.12	<5	8.27
Finlay Sampling Station	14-Nov-17	0.0072	0.0009	0.00006	0.005	0.093	<5	8.24
Stayte Station	14-Nov-17	0.0071	0.0031	0.00035	0.008	0.081	<5	8.24
Balsam	14-Nov-17	0.0064	0.0379	0.00052	0.011	0.061	<5	8.22
Oxford & Buena Vista Station	14-Nov-17	0.0059	0.0009	0.00013	0.006	0.072	<5	8.21
Everall Sample Station	21-Nov-17	0.0056	0.0008	0.00005	0.005	0.026	<5	7.98
Malabar Sample Station	21-Nov-17	0.0055	0.0030	0.00034	0.0098	0.024	<5	8.01
Chestnut Street	21-Nov-17	0.0056	0.0019	0.00017	0.014	0.021	<5	8.02
Russell Avenue Sample Station	21-Nov-17	0.0085	0.0010	0.00014	0.006	0.13	<5	8.12
Roper PRV - High Zone	21-Nov-17	0.0086	0.0007	0.00004	0.005	0.10	<5	8.13
Roper PRV - High Zone	22-Nov-17	0.0087	0.0037	0.00049	0.0099	0.13	<5	8.15
Finlay Sampling Station	22-Nov-17	0.0077	0.0006	0.00004	0.007	0.096	<5	8.14
Stayte Station	22-Nov-17	0.0077	0.0045	0.00040	0.009	0.083	<5	8.13
Balsam	22-Nov-17	0.0079	0.0534	0.00044	0.0097	0.076	<5	8.15
Oxford & Buena Vista Station	22-Nov-17	0.0073	0.0072	0.00025	0.008	0.085	<5	8.12
Everall Sample Station	28-Nov-17	0.0057	0.0010	0.00006	<0.004	0.023	<5	8.01
Mann Park Sample Station	28-Nov-17	0.0057	0.0070	0.00020	<0.004	0.021	<5	8.05
Marine Drive Sample Station	28-Nov-17	0.0056	0.0032	0.00021	0.007	0.022	<5	8.05
Russell Avenue Sample Station	28-Nov-17	0.0085	0.0008	0.000095	0.006	0.13	<5	8.15
Roper PRV - High Zone	28-Nov-17	0.0085	<0.0005	0.00005	0.005	0.12	<5	8.13
Stevens Sampling Station	28-Nov-17	0.0084	0.0021	0.00010	0.006	0.12	<5	8.14
Finlay Sampling Station	29-Nov-17	0.0078	0.0008	0.00006	0.006	0.098	<5	8.08
Stayte Station	29-Nov-17	0.0077	0.0026	0.00027	0.009	0.078	<5	8.13
Balsam	29-Nov-17	0.0067	0.0326	0.00037	0.009	0.064	<5	8.11
Oxford & Buena Vista Station	29-Nov-17	0.0066	0.0009	0.000099	0.009	0.077	<5	8.12
Everall Sample Station	05-Dec-17	0.0055	0.0009	0.00007	<0.004	0.024	<5	7.60
Malabar Sample Station	05-Dec-17	0.0054	0.0026	0.00034	<0.004	0.019	<5	7.77
Chestnut Street	05-Dec-17	0.0054	0.0017	0.00020	0.018	0.019	<5	7.85
Russell Avenue Sample Station	05-Dec-17	0.0084	0.00098	0.00013	0.007	0.14	<5	7.95
Roper PRV - High Zone	05-Dec-17	0.0078	0.0009	0.00008	<0.004	0.099	<5	7.94

Oxford & Merklin Chlorination Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese	Colour	pH
		mg/L	mg/L	mg/L	mg/L	mg/L	Colour Units	
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001	5	
Guideline Limit		0.0100	1	0.01	0.3	0.05		6.5 - 8.5
Roper PRV - High Zone	06-Dec-17	0.0082	0.0024	0.00029	0.009	0.12	<5	7.85
Finlay Sampling Station	06-Dec-17	0.0070	0.0006	0.00001	0.007	0.082	<5	7.89
Stayte Station	06-Dec-17	0.0073	0.0016	0.00017	0.007	0.069	<5	7.92
Balsam	06-Dec-17	0.0074	0.0013	0.00023	0.13	0.45	<5	7.92
Oxford & Buena Vista Station	06-Dec-17	0.0064	0.0071	0.00026	0.008	0.087	<5	7.91
Everall Sample Station	12-Dec-17	0.0056	0.0008	0.00006	0.005	0.024	<5	7.71
Mann Park Sample Station	12-Dec-17	0.0056	0.0046	0.00022	0.005	0.022	<5	7.81
Marine Drive Sample Station	12-Dec-17	0.0054	0.0026	0.00018	0.011	0.020	<5	7.83
Russell Avenue Sample Station	12-Dec-17	0.0088	0.0009	0.00013	0.005	0.12	<5	7.95
Roper PRV - High Zone	12-Dec-17	0.0080	0.0010	0.00005	0.006	0.10	<5	7.94
Stevens Sampling Station	13-Dec-17	0.0076	0.0019	0.00013	0.006	0.094	<5	7.73
Finlay Sampling Station	13-Dec-17	0.0067	0.0009	0.00006	0.005	0.059	<5	7.83
Stayte Station	13-Dec-17	0.0072	0.0016	0.00018	0.009	0.075	<5	7.88
Balsam	13-Dec-17	0.0077	0.0016	0.00038	0.008	0.085	<5	7.89
Oxford & Buena Vista Station	13-Dec-17	0.0064	0.0089	0.00060	0.008	0.065	<5	7.87
Everall Sample Station	19-Dec-17	0.0054	0.0009	0.00001	<0.004	0.025	<5	7.63
Malabar Sample Station	19-Dec-17	0.0055	0.0025	0.00028	0.015	0.023	<5	7.79
Chestnut Street	19-Dec-17	0.0056	0.0017	0.00012	0.016	0.020	<5	7.88
Russell Avenue Sample Station	19-Dec-17	0.0084	0.0009	0.00007	0.007	0.13	<5	7.98
Roper PRV - High Zone	19-Dec-17	0.0080	0.0012	0.00002	0.005	0.11	<5	7.99
Roper PRV - High Zone	20-Dec-17	0.0087	0.0022	0.00028	0.009	0.12	<5	8.13
Finlay Sampling Station	20-Dec-17	0.0070	0.0013	0.00003	0.007	0.072	<5	8.13
Stayte Station	20-Dec-17	0.0071	0.0023	0.00022	0.008	0.072	<5	8.16
Balsam	20-Dec-17	0.0081	0.0014	0.00027	0.010	0.093	<5	8.17
Oxford & Buena Vista Station	20-Dec-17	0.0064	0.0013	0.00007	0.007	0.080	<5	8.13