

Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese
		mg/L	mg/L	mg/L	mg/L	mg/L
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001
Guideline Limit		0.0100	1	0.01	0.3	0.05
15600 Blk. Marine Drive	20-Jan-17	0.0075	0.0190	0.000116	0.006	0.029
15200 Blk. Marine Drive	23-Jan-17	0.0057	0.0026	0.000022	<0.004	0.031
Oxford Well #1	25-Jan-17	0.0067	0.0005	0.000276	0.005	0.058
Oxford Well #2	25-Jan-17	0.0046	0.0049	0.000129	<0.004	0.002
Oxford Well #3	25-Jan-17	0.0062	0.0012	0.000065	0.004	0.181
High St Well #4	25-Jan-17	0.0027	0.0012	0.001030	0.054	0.187
Buena Vista Well #5	25-Jan-17	0.0079	0.0023	0.000096	0.022	0.012
Merklin Well #6	25-Jan-17	0.0086	<0.0005	0.000099	0.005	0.142
Merklin Well #7	25-Jan-17	0.0080	0.0010	0.000178	0.007	0.111
15000 Blk. Russell Ave	31-Jan-17	0.0056	0.125	0.001470	0.020	0.086
1400 Blk. Martin St	06-Feb-17	0.0057	0.0070	0.000014	<0.004	0.057
1400 Blk. Vidal St	09-Feb-17	0.0059	0.0083	0.000180	<0.004	0.061
15100 Blk. Prospect Ave	21-Feb-17	0.0066	0.0042	0.000036	<0.004	0.028
1300 Blk. Foster St	02-Mar-17	<0.0001	0.0010	0.000185	<0.004	0.029
15100 Blk. B-Vista	13-Mar-17	0.0068	0.0115	0.000057	<0.004	0.128
Well #6	14-Mar-17	0.0088	Monthly Merklin Arsenic Sampling			
Well #7	14-Mar-17	0.0081				
15000 Blk. Victoria Ave	28-Mar-17	0.0062	0.0083	0.000227	0.010	0.020
1200 Blk. Foster St	30-Mar-17	0.0061	0.0098	0.000069	<0.004	0.017
Merklin Well #6	11-Apr-17	0.0089	<0.0005	0.000027	<0.004	0.135
Merklin Well #7	11-Apr-17	0.0094	0.0136	0.000517	0.149	0.109
High St Well #4	11-Apr-17	0.0040	0.0047	0.000847	0.330	0.156
Oxford Well #1	13-Apr-17	0.0060	0.0039	0.000514	<0.004	0.050
Oxford Well #2	13-Apr-17	0.0045	0.0069	0.000138	0.173	0.002
Oxford Well #3	13-Apr-17	0.0064	0.0015	0.0000992	<0.004	0.179
14800 Blk. North Bluff	27-Apr-17	0.0058	0.0379	0.000487	0.004	0.043
15000 Blk. Roper	03-May-17	0.0055	0.0285	0.000170	<0.004	0.012
1200 Blk. Martin	19-May-17	0.0079	0.0072	0.000364	0.006	0.11

Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese
		mg/L	mg/L	mg/L	mg/L	mg/L
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001
Guideline Limit		0.0100	1	0.01	0.3	0.05
1400 Blk. Nichol	24-May-17	0.0058	0.0162	0.000092	0.006	0.490
Well #6	25-May-17	0.0092	Monthly Merklin Arsenic Sampling			
Well #7	25-May-17	0.0086				
13800 Blk. Marine Drive	29-May-17	0.0058	0.0293	0.000239	<0.004	0.005
13900 Blk. Marine Drive	29-May-17	0.0059	0.0074	0.000219	<0.004	0.006
1100 Blk. Lee St	30-May-17	0.0089	0.0077	0.000027	0.007	0.11
14200 Blk. Vine Ave	02-Jun-17	0.0060	0.0151	0.00034	<0.004	0.007
Customer Concern 01	13-Jun-17	0.0059	0.1008	0.00150	0.007	0.028
Well #6	28-Jun-17	0.0089	Monthly Merklin Arsenic Sampling			
Well #7	28-Jun-17	0.0085				
Customer Concern 02	28-Jun-17	0.0085	0.0070	0.00009	<0.004	0.11
Customer Concern 03	13-Jul-17	0.0085	0.0136	0.00004	0.005	0.13
Customer Concern 04	18-Jul-17	0.0059	0.0263	0.00010	<0.004	0.053
Well #1	28-Jul-17	0.0067	0.0041	0.00025	<0.004	0.052
Well #2	28-Jul-17	0.0046	0.0040	0.00005	<0.004	0.004
Well #3	28-Jul-17	0.0063	0.0008	0.00005	<0.004	0.18
Well #6	28-Jul-17	0.0090	0.0006	0.00008	<0.004	0.13
Well #7	28-Jul-17	0.0085	0.0039	0.00141	<0.004	0.10
Customer Concern 05	03-Aug-17	0.0075	0.0125	0.00018	0.011	0.10
Peace Arch Hospital	10-Aug-17	0.0089	0.0011	0.00007	0.004	0.13
Customer Concern 06	19-Sep-17	0.0079	0.0028	0.00016	0.005	0.12
Well #6	29-Sep-17	0.0092	Monthly Merklin Arsenic Sampling			
Well #7	29-Sep-17	0.0084				
Customer Concern 07	04-Oct-17	0.0071	0.0290	0.00011	0.006	0.086

Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese
		mg/L	mg/L	mg/L	mg/L	mg/L
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001
Guideline Limit		0.0100	1	0.01	0.3	0.05
Well #1	25-Oct-17	0.0066	0.0057	0.00019	<0.004	0.048
Well #2	25-Oct-17	0.0045	0.0049	0.00004	0.005	0.001
Well #3	25-Oct-17	0.0064	0.0007	0.00002	0.006	0.19
Well #6	25-Oct-17	0.0106	0.0009	0.00014	0.012	0.14
Well #7	25-Oct-17	0.0106	0.0009	0.00013	<0.004	0.11
Well #8	25-Oct-17	0.0071	0.0008	0.00006	0.032	0.17
Well #6	07-Nov-17	0.0088	Monthly Merklin Arsenic Sampling			
Well #7	07-Nov-17	0.0083				
Well #6	28-Nov-17	0.0090	Monthly Merklin Arsenic Sampling			
Well #7	28-Nov-17	0.0084				
Well #6	28-Dec-17	0.0088	Monthly Merklin Arsenic Sampling			
Well #7	28-Dec-17	0.0084				