

White Rock Water Sampling Summary Results -May 17 2016

Sample Location	Date Sampled	METALS					BACTERIA	
		Arsenic	Copper	Lead	Iron	Manganese	Total Coliforms	Escherichia Coli
Units		mg/L	mg/L	mg/L	mg/L	mg/L	MPN/100mL	MPN/100mL
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001	1.0	1.0
Guideline Allowable Limit		0.0100	1.000	0.0100	0.300	0.050	0.0	0.0
14800 Blk. Buena Vista Avenue (Main Shop)	16-May-16	0.0092	0.015	<0.0001	<0.005	0.009	<1.0	<1.0
Everall Station	16-May-16	0.0063	0.002	<0.0001	0.009	0.075	<1.0	<1.0
Malabar Station	16-May-16	0.0050	0.003	<0.0001	0.010	0.019	<1.0	<1.0
Mann Park Station	16-May-16	0.0057	0.012	<0.0001	0.007	0.031	<1.0	<1.0
Marine Station	16-May-16	0.0036	0.004	<0.0001	0.033	0.025	<1.0	<1.0
Merklin Reservoir	16-May-16	0.0095	<0.001	<0.0001	0.009	0.124	<1.0	<1.0
Roper Station	16-May-16	0.0056	0.002	<0.0001	0.015	0.056	<1.0	<1.0
Russell Ave Station	16-May-16	0.0062	0.002	0.0004	0.008	0.056	<1.0	<1.0
Stayte Station	16-May-16	0.0080	0.007	0.0005	0.040	0.025	<1.0	<1.0
Stevens Station	16-May-16	0.0058	0.003	<0.0001	0.013	0.070	<1.0	<1.0
WR Washroom	16-May-16	0.0086	0.098	0.0014	0.059	0.129	<1.0	<1.0