

Bacterial Results - 2022

Microbiological Analysis MPN / 100mL	Date	Guideline Limit 0 per 100 ml	# of Samples	Pass	Fail	Guideline Comments
Total Coliforms	4-Jan-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	4-Jan-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	5-Jan-22	0 per 100 mL	4	4	0	Below Guideline
Escherichia Coli	5-Jan-22	0 per 100 mL	4	4	0	Below Guideline
Total Coliforms	10-Jan-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	10-Jan-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	11-Jan-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	11-Jan-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	17-Jan-21	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	17-Jan-21	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	18-Jan-21	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	18-Jan-21	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	24-Jan-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	24-Jan-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	25-Jan-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	25-Jan-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	31-Jan-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	31-Jan-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	1-Feb-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	1-Feb-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	7-Feb-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	7-Feb-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	8-Feb-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	8-Feb-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	14-Feb-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	14-Feb-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	15-Feb-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	15-Feb-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	22-Feb-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	22-Feb-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	23-Feb-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	23-Feb-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	28-Feb-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	28-Feb-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	1-Mar-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	1-Mar-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	7-Mar-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	7-Mar-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	8-Mar-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	8-Mar-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	15-Mar-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	15-Mar-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	21-Mar-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	22-Mar-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	29-Mar-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	30-Mar-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	4-Apr-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	5-Apr-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	11-Apr-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	12-Apr-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	19-Apr-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	20-Apr-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	26-Apr-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	27-Apr-22	0 per 100 mL	7	7	0	Below Guideline

Microbiological Analysis MPN / 100mL	Date	Guideline Limit 0 per 100 ml	# of Samples	Pass	Fail	Guideline Comments
Total Coliforms	2-May-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	2-May-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	3-May-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	3-May-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	9-May-22	0 per 100 mL	6	6	0	Below Guideline
Escherichia Coli	9-May-22	0 per 100 mL	6	6	0	Below Guideline
Total Coliforms	11-May-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	11-May-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	16-May-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	16-May-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	17-May-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	17-May-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	24-May-22	0 per 100 mL	6	6	0	Below Guideline
Escherichia Coli	24-May-22	0 per 100 mL	6	6	0	Below Guideline
Total Coliforms	25-May-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	25-May-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	30-May-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	30-May-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	31-May-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	31-May-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	6-Jun-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	6-Jun-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	7-Jun-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	7-Jun-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	13-Jun-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	14-Jun-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	20-Jun-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	21-Jun-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	27-Jun-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	28-Jun-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	4-Jul-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	5-Jul-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	11-Jul-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	12-Jul-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	18-Jul-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	19-Jul-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	25-Jul-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	26-Jul-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	2-Aug-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	3-Aug-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	8-Aug-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	9-Aug-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	15-Aug-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	16-Aug-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	22-Aug-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	23-Aug-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	29-Aug-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	30-Aug-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	6-Sep-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	7-Sep-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	12-Sep-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	13-Sep-22	0 per 100 mL	7		0	Below Guideline
Total Coliforms	20-Sep-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	21-Sep-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	26-Sep-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	27-Sep-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	3-Oct-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	4-Oct-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	11-Oct-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	12-Oct-22	0 per 100 mL	8	8	0	Below Guideline

Microbiological Analysis MPN / 100mL	Date	Guideline Limit 0 per 100 ml	# of Samples	Pass	Fail	Guideline Comments
Total Coliforms	17-Oct-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	18-Oct-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	24-Oct-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	25-Oct-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	1-Nov-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	2-Nov-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	8-Nov-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	9-Nov-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	14-Nov-22	0 per 100 mL	6	6	0	Below Guideline
Escherichia Coli	15-Nov-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	21-Nov-22	0 per 100 mL	7	7	0	Below Guideline
Escherichia Coli	22-Nov-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	30-Nov-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	5-Dec-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	6-Dec-22	0 per 100 mL	8	8	0	Below Guideline
Escherichia Coli	12-Dec-22	0 per 100 mL	7	7	0	Below Guideline
Total Coliforms	13-Dec-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	20-Dec-22	0 per 100 mL	8	8	0	Below Guideline
Total Coliforms	28-Dec-22	0 per 100 mL	7	7	0	Below Guideline