

Non Routine Water Quality Results for Source and Distribution Water 2022

Sampling Point Name	Date Sampled	TC MPN / 100 ml	E-coli MPN / 100 ml	Comments
Stevens Sample Station**	Jan 5 2022	<1.0	<1.0	Below MAC
1256 Finlay St	Jan 7 2022	<1.0	<1.0	Below MAC
Roper Sample Station	Jan 10 2022	<1.0	<1.0	Below MAC
Weatherby/Russell Medical Building	Jan 13 2022	<1.0	<1.0	Below MAC
Roper PRV	Jan 24 2022	<1.0	<1.0	Below MAC
Roper PRV	Feb 14 2022	<1.0	<1.0	Below MAC
Well #1	Feb 18 2022	<1.0	<1.0	Below MAC
Finaly/Russell	Mar 18 2022	<1.0	<1.0	Below MAC
Roper PRV	Apr 26 2022	<1.0	<1.0	Below MAC
Phoenix and Malabar	May 19 2022	<1.0	<1.0	Below MAC
Phoenix and Malabar #2 / 4.4 °C	May 20 2022	<1.0	<1.0	Below MAC
Chestnut Stn Resample	July 7 2022	<1.0	<1.0	Below MAC
Roper PRV	Oct 12 2022	<1.0	<1.0	Below MAC
Amount of Times 1.0 or Higher:		0	0	