

May 27, 2022

FOI No: 2022-09

VIA EMAIL – Redacted

Redacted

Dear Redacted

Re: Request for Information
Freedom of Information and Protection of Privacy Act

The City of White Rock has reviewed your request for access to the following information pursuant to the Freedom of Information and Protection of Privacy Act (the "Act"):

- *the Fire Department report with the description of the findings re: April 15, 2022, fire alarm incident at 306 - 15154 Russell Avenue*

Access to the White Rock Fire Department Incident Report is available. However, some of the information in this record is excepted from the disclosure requirements of the Act. I have severed the excepted information so that I could disclose to you the remaining information as attached.

The severed information is excepted from disclosure under section 22 of the Act. Severing under section 22 is necessary to avoid disclosing third-party personal information without permission.

Please contact our office if you have any questions or concerns.

Sincerely,



Ken Overton
Manager, Property, Risk Management, and FOI
604-541-2104

Att.

Corporate Administration
P: 604.541.2212 | F: 604.541.9348

City of White Rock
15322 Buena Vista Avenue, White Rock BC, Canada V4B 1Y6

WHITE ROCK
City by the Sea!

www.whiterockcity.ca

If you believe that the City of White Rock has been unreasonable in its handling of your request, you may ask the Information and Privacy Commissioner to review our response. You have 30 days from receipt of this notice to request a review by writing to:

Office of the Information and Privacy Commissioner
3rd Floor, 756 Fort Street
Victoria BC V8W 1H2

Should you decide to request a review, please provide the Commissioner's office with:

1. your name, address, and telephone number;
2. a copy of this letter;
3. a copy of your original request sent to the City of White Rock; and
4. the reasons or grounds upon which you are requesting the review.

White Rock Fire Department Incident Report

May 2, 2022

Incident Number: 22-033546
Apt/Unit
Incident Address: 15152 RUSSELL AVE, WHITE ROCK
Cross Street: FOSTER ST
Dispatch Type ALARMS RINGING - MR / COMMERCIAL
Incident Type: AMC Alarm - MultiRes / Commercial
Incident Begin Time: 04/15/2022 7:59:39
Incident End Time: 04/15/2022 8:41:08
Building Name:

Officer Reporting:	[N]	Drug Lab:	0
Station Area:	White Rock Hall 1	Grow Op:	0
Shift:	A Shift	Secondary Suite:	0
Incident Commander:	[N]	Total Injuries:	
False Alarm:	0	Total Manhours:	
Liability Release:	0	Total Manpower:	9

Bench Marks

Command Established:	04/15/2022 08:04:02	Working Fire:	
Ambulance on Scene:		1st Search Completed:	
Police on Scene:		2nd Search Completed:	
Police File Number:		Loss Stopped:	
Property Ref on Scene:		Situation under Control:	
Volunteers Paged:	04/15/2022 08:00:56	Post Incident Watch Posted:	
Duty Chief Notified:		Inspector Paged:	
Career Callout Initiated:		BC Hydro on Scene:	
FF with Ambulance:		Gas Utility on Scene:	
FF Return to Crew:		Fire Commissioner Notified:	
Tow Truck Notified:		Ministry of Environment:	
Public Works Notified:		Provincial Hiways Notified:	
		Min. of Forests Notified:	

Officer/Crew Notes

Notes: AC Bancroft

E1 response to 15152 miramar high rise for an alarms ringing incident ,, crews we're updated by the cad enroute of sprinkler flow on the 3 rd floor ,, E1 arrived on scene found nothing showing sides. A and B setup miramar command was mobile and investigating ,, once in the lobby I was met by the runner, she said sprinkler flow in suite 306 in the washroom ,, no smoke or fire possibly a head knocked off, all units were then updated and FFs Farrant Pearson. Took the keys and took over elevator to investigate ,, they confirmed no fire and shut off the 3 rd floor sprinkler to stop the water flow , residents were informed of the alarm and told to stay in there suits as there was no danger and they did accordingly ,, e2 members were instructed to 306 to provide salvage assistance ,, allot of water was in the suite, E1 crews also removed the toilet to help in the draining ,, approx 6 suite were effected Floors 1 through 3 and the lobby ,, home owner was denying any wrong and was interviewed by C2 McLeod ,, E1 and e2 continued with water vac and salvage as long as possible ,, .. the building was written up and posted for fire watch activity until there system was repaired .. E1 and e 2 clearedter was in the suite, E1 crews also removed the toilet to help in the draining ,, approx 6 suite were effected Floors 1 through 3 and the lobby ,, home owner was denying any wrong and was interviewed by C2 McLeod ,, E1 and e2 continued with water vac and salvage as long as possible ,, .. the building was written up and posted for fire watch activity until there system was repaired .. E1 and

White Rock Fire Department Incident Report

May 2, 2022

e 2 cleared.

Redacted S. 22

Notes: AC Bancroft 2

Redacted S. 22 owner of #306

s. 22 roading tenant

Redacted S. 22 strata

Time:	Dispatch Notes
04/15/2022 08:41:08	Transferred from CAD
04/15/2022 08:37:03	cmd - e1 evail from scene, cmd terminated
04/15/2022 08:16:11	CMD - isolated the problem. overhaul
04/15/2022 08:12:37	E2 - w/4
04/15/2022 08:07:07	Redacted S. 22
04/15/2022 08:06:33	coming from the unit 306
04/15/2022 08:06:17	flood on the 3rd floor
04/15/2022 08:06:17	hall on air
04/15/2022 08:06:08	Linked to incident 'ALARMS - NON-RES: 15152 RUSSELL AVE, WHITE
04/15/2022 08:06:08	Change from blank address to Change from 15152 RUSSELL AVE, WHITE
04/15/2022 08:05:57	Change of mapped location
04/15/2022 08:05:57	Department assigned 'WHITE ROCK FIRE DEPARTMENT'
04/15/2022 08:03:51	E1 - nothing showing A/B, Miramar cmd.
04/15/2022 08:02:14	crews updt
04/15/2022 08:01:31	dva
04/15/2022 08:00:13	Dispatch viewed Alert details.
04/15/2022 08:00:10	zone 1 fire alarm
04/15/2022 08:00:09	viewed alerts
04/15/2022 08:00:05	wcb with pr eta
04/15/2022 08:00:00	alarm co sdi 604 777 3333
04/15/2022 07:59:53	zone 1 fire alarm
04/15/2022 07:59:52	Incident dispatcher Assigned: 00314
04/15/2022 07:59:52	Dispatch acknowledged incident.
04/15/2022 07:59:44	Department assigned 'WHITE ROCK FIRE DEPARTMENT'
04/15/2022 07:59:42	Initial incident type selected 'ALARMS - NON-RES ALARMS RINGING - MR /
04/15/2022 07:59:39	Call initiated from command line text:

Apparatus Attending

Apparatus	Dispatch Time	On Route Time	Onscene Time	Return Service Time	Return Quarter Time/Date
-----------	---------------	---------------	--------------	---------------------	--------------------------

White Rock Fire Department Incident Report

May 2, 2022

WR Engine 1 04/15/2022 07:59:50 04/15/2022 08:01:28 04/15/2022 08:04:03 04/15/2022 08:37:11

WR Engine 2 04/15/2022 07:59:50 04/15/2022 08:12:30 04/15/2022 08:14:20 04/15/2022 08:37:13

WR 410 04/15/2022 07:59:56

04/15/2022 08:10:28

WR Deputy Chief 04/15/2022 08:02:29 04/15/2022 08:18:16 04/15/2022 08:18:21 04/15/2022 08:37:23

Attendees

Jacob Amisano

Paid On Call Firefighter

Mike Bancroft

Firefighter

Cody Dunn

Paid On Call Firefighter

Paul Farrant

Firefighter

Eric Kameka

Firefighter

Scott Pearson

Paid On Call Firefighter

Darren Phillips

Paid On Call Firefighter

Kalen Stewart

Paid on Call Recruit

John Webb

Paid on Call Recruit
