

## Non Routine Water Quality Results for Source and Distribution Water 2023

Sampling Point Name	Date Sampled	TC MPN / 100 ml	E-coli MPN / 100 ml	Comments
14811 Buena Vista	16-Jan-23	<1	<1	Below MAC
Everall Stn	19-Jan-23	<1	<1	Below MAC
Russell Stn	19-Jan-23	<1	<1	Below MAC
Marine & Stevens St #1	25-Apr-23	<1	<1	Below MAC
Marine & Stevens St #2	27-Apr-23	<1	<1	Below MAC
Finlay Station Resample 2	12-Jun-23	<1	<1	Below MAC
Stevens St & Marine Dr -Resample	23-Jun-23	<1	<1	Below MAC
Chestnut & North Bluff - Resample	4-Aug-23	<1	<1	Below MAC
Finaly Sample Station 1130	29-Sep-23	<1	<1	Below MAC
15611 Marine Dr	8-Dec-23	<1	<1	Below MAC
1171 Lee St	12-Dec-23	<1	<1	Below MAC
<b>Amount of Times 1.0 or Higher:</b>		0	0	