

THM & HAA RESULTS 2023

Sample	Unit of Measure	Nominal Detection Limit	Sample Location				Sampled Date
			Marine Dr Station	Roper PRV	Stevens Station	Stayte Station	
Chloroform	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	30-Jan-23
Bromodichloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	30-Jan-23
Dibromochloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	30-Jan-23
Bromoform	mg/L	0.001	<0.001	<0.001	0.001	<0.001	30-Jan-23
Total THMs	mg/L	0.001	<0.001	<0.001	0.001	<0.001	30-Jan-23
Dibromofluoromethane	%	50-140	94	100	95	96	30-Jan-23
Toluene-d8	%	50-140	101	99	100	101	30-Jan-23
Bromofluorobenzene	%	50-140	98	97	94	94	30-Jan-23
Monochloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	30-Jan-23
Monobromoacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	30-Jan-23
Dichloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	30-Jan-23
Bromochloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	30-Jan-23
Dibromoacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	30-Jan-23
Trichloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	30-Jan-23
Total HAA6	ug/L	12.0	<12.0	<12.0	<12.0	<12.0	30-Jan-23
2,3-Dibromopropionic Acid	%	50-150	84	100	93	97	30-Jan-23

Sample	Unit of Measure	Nominal Detection Limit	Sample Location				Sampled Date
			Marine Dr Station	Roper PRV	Stevens Station	Stayte Station	
Chloroform	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	17-Apr-23
Bromodichloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	17-Apr-23
Dibromochloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	17-Apr-23
Bromoform	mg/L	0.001	<0.001	0.001	<0.001	<0.001	17-Apr-23
Total THMs	mg/L	0.001	<0.001	0.001	<0.001	<0.001	17-Apr-23
Dibromofluoromethane	%	50-140	104	111	102	107	17-Apr-23
Toluene-d8	%	50-140	98	94	102	99	17-Apr-23
Bromofluorobenzene	%	50-140	104	105	102	100	17-Apr-23
Monochloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	17-Apr-23
Monobromoacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	17-Apr-23
Dichloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	17-Apr-23
Bromochloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	17-Apr-23
Dibromoacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	17-Apr-23
Trichloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	17-Apr-23
Total HAA6	ug/L	12.0	<12.0	<12.0	<12.0	<12.0	17-Apr-23
2,3-Dibromopropionic Acid	%	50-150	93	87	84	82	17-Apr-23

Sample	Unit of Measure	Nominal Detection Limit	Sample Location				Sampled Date
			Marine Dr Station	Roper PRV	Stevens Station	Stevens & Marine	
Chloroform	mg/L	0.001	<0.5	<0.5	<0.5	<0.5	24-Jul-23
Bromodichloromethane	mg/L	0.001	<0.5	<0.5	<0.5	<0.5	24-Jul-23
Dibromochloromethane	mg/L	0.001	<0.5	<0.5	<0.5	<0.5	24-Jul-23
Bromoform	mg/L	0.001	<0.5	<0.5	<0.5	<0.5	24-Jul-23
Total THMs	mg/L	0.001	<2.0	<2.0	<2.0	<2.0	24-Jul-23
Dibromofluoromethane	%	50-140	90	90	90	94	24-Jul-23
Toluene-d8	%	50-140	110	110	110	103	24-Jul-23
Bromofluorobenzene	%	50-140	96	101	102	108	24-Jul-23
Monochloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	24-Jul-23
Monobromoacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	24-Jul-23
Dichloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	24-Jul-23
Bromochloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	24-Jul-23
Dibromoacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	24-Jul-23
Trichloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	24-Jul-23
Total HAA6	ug/L	12.0	<12.0	<12.0	<12.0	<12.0	24-Jul-23
2,3-Dibromopropionic Acid	%	50-150	68	97	68	94	24-Jul-23

Sample	Unit of Measure	Nominal Detection Limit	Sample Location				Sampled Date
			Marine Dr Station	Roper PRV	Stevens Station	Stevens & Marine	
Chloroform	mg/L	0.001	<0.5	<0.5	<0.5	<0.5	24-Oct-23
Bromodichloromethane	mg/L	0.001	<0.5	<0.5	<0.5	<0.5	24-Oct-23

Dibromochloromethane	mg/L	0.001	<0.5	<0.5	0.6	<0.5	24-Oct-23
Bromoform	mg/L	0.001	<0.5	<0.5	1.1	0.5	24-Oct-23
Total THMs	mg/L	0.001	<2.0	<2.0	1.7	0.5	24-Oct-23
Dibromofluoromethane	%	50-140	108	114	114	110	24-Oct-23
Toluene-d8	%	50-140	116	120	116	112	24-Oct-23
Bromofluorobenzene	%	50-140	104	107	104	107	24-Oct-23
Monochloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	24-Oct-23
Monobromoacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	24-Oct-23
Dichloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	24-Oct-23
Bromochloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	24-Oct-23
Dibromoacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	24-Oct-23
Trichloroacetic Acid	ug/L	2.0	<2.0	<2.0	<2.0	<2.0	24-Oct-23
Total HAA6	ug/L	12.0	<12.0	<12.0	<12.0	<12.0	24-Oct-23
2,3-Dibromopropionic Acid	%	50-150	100	99	110	100	24-Oct-23